

Date: 08 May 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

APRIL 2025 TREATED WATER (FINAL) RESULTS

Please find April 2025 Treated Water (Final) results tabulated below for samples received during April 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
01-Apr-25	2368492	TQU002	Mnqumeni Final	Al (AE)	75.7	±7.6%	µg Al/L
01-Apr-25	2368487	TQU002	Mnqumeni Final	Batch No.*	6246	-	-
01-Apr-25	2368487	TQU002	Mnqumeni Final	Cl2 (F) OS*	0.76	-	mg Cl2/L
01-Apr-25	2368487	TQU002	Mnqumeni Final	Cl2 (T) OS*	0.99	-	mg Cl2/L
01-Apr-25	2368488	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
01-Apr-25	2368487	TQU002	Mnqumeni Final	Coll Time OS*	06:30	-	-
01-Apr-25	2368491	TQU002	Mnqumeni Final	Conductivity	13.6	±1.5%	mS/m
01-Apr-25	2368488	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
01-Apr-25	2368492	TQU002	Mnqumeni Final	Fe (AE)	0.04	±5.4%	mg Fe/L
01-Apr-25	2368488	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
01-Apr-25	2368492	TQU002	Mnqumeni Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
01-Apr-25	2368490	TQU002	Mnqumeni Final	Odour*	Mild Chlorinous	-	-
01-Apr-25	2368487	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
01-Apr-25	2368490	TQU002	Mnqumeni Final	Taste*	Nil	-	-
01-Apr-25	2368487	TQU002	Mnqumeni Final	Temperature OS*	19.2	-	°C
01-Apr-25	2368490	TQU002	Mnqumeni Final	Turbidity	0.5	±6.1%	NTU
01-Apr-25	2368503	TSQ002	Esiqanduleni Final	Al (AE)	86.7	±7.6%	µg Al/L
01-Apr-25	2368498	TSQ002	Esiqanduleni Final	Batch No.*	6246	-	-
01-Apr-25	2368498	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	1.37	-	mg Cl2/L
01-Apr-25	2368498	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.50	-	mg Cl2/L
01-Apr-25	2368499	TSQ002	Esiqanduleni Final	Coliforms*	3	±15%	MPN/100mL
01-Apr-25	2368498	TSQ002	Esiqanduleni Final	Coll Time OS*	08:20	-	-
01-Apr-25	2368502	TSQ002	Esiqanduleni Final	Conductivity	8.39	±1.5%	mS/m
01-Apr-25	2368499	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
01-Apr-25	2368503	TSQ002	Esiqanduleni Final	Fe (AE)	0.04	±5.4%	mg Fe/L
01-Apr-25	2368499	TSQ002	Esiqanduleni Final	HPC 37*	13	±21%	cfu/mL
01-Apr-25	2368503	TSQ002	Esiqanduleni Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
01-Apr-25	2368498	TSQ002	Esiqanduleni Final	pH OS*	7.60	-	-
01-Apr-25	2368498	TSQ002	Esiqanduleni Final	Temperature OS*	21.4	-	°C
01-Apr-25	2368501	TSQ002	Esiqanduleni Final	Turbidity	1.1	±6.1%	NTU
02-Apr-25	2369002	TBU002	Bulwer Final	Batch No.*	6246	-	-
02-Apr-25	2369002	TBU002	Bulwer Final	Cl2 (F) OS*	1.07	-	mg Cl2/L
02-Apr-25	2369002	TBU002	Bulwer Final	Cl2 (T) OS*	1.19	-	mg Cl2/L
02-Apr-25	2369003	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
02-Apr-25	2369002	TBU002	Bulwer Final	Coll Time OS*	10:09	-	-
02-Apr-25	2369006	TBU002	Bulwer Final	Conductivity	4.37	±1.5%	mS/m
02-Apr-25	2369003	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
02-Apr-25	2369007	TBU002	Bulwer Final	Fe (AE)	0.17	±5.4%	mg Fe/L
02-Apr-25	2369003	TBU002	Bulwer Final	HPC 37*	10	±21%	cfu/mL
02-Apr-25	2369002	TBU002	Bulwer Final	pH OS*	7.60	-	-
02-Apr-25	2369002	TBU002	Bulwer Final	Temperature OS*	20.1	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

02-Apr-25	2369005	TBU002	Bulwer Final	Turbidity	3.1	±6.1%	NTU
02-Apr-25	2369023	THL002	Hlanganani Final	Batch No.*	6246	-	-
02-Apr-25	2369023	THL002	Hlanganani Final	Cl2 (F) OS*	0.35	-	mg Cl2/L
02-Apr-25	2369023	THL002	Hlanganani Final	Cl2 (T) OS*	0.58	-	mg Cl2/L
02-Apr-25	2369024	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
02-Apr-25	2369023	THL002	Hlanganani Final	Coll Time OS*	11:05	-	-
02-Apr-25	2369027	THL002	Hlanganani Final	Conductivity	8.29	±1.5%	mS/m
02-Apr-25	2369024	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
02-Apr-25	2369024	THL002	Hlanganani Final	HPC 37*	0	±21%	cfu/mL
02-Apr-25	2369023	THL002	Hlanganani Final	pH OS*	7.40	-	-
02-Apr-25	2369023	THL002	Hlanganani Final	Temperature OS*	19.9	-	°C
02-Apr-25	2369026	THL002	Hlanganani Final	Turbidity	0.2	±6.1%	NTU
02-Apr-25	2369049	TMQA002	Mqatsheni Final	Batch No.*	6240	-	-
02-Apr-25	2369049	TMQA002	Mqatsheni Final	Cl2 (F) OS*	1.20	-	mg Cl2/L
02-Apr-25	2369049	TMQA002	Mqatsheni Final	Cl2 (T) OS*	1.31	-	mg Cl2/L
02-Apr-25	2369050	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
02-Apr-25	2369049	TMQA002	Mqatsheni Final	Coll Time OS*	07:20	-	-
02-Apr-25	2369053	TMQA002	Mqatsheni Final	Conductivity	24.9	±1.5%	mS/m
02-Apr-25	2369050	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
02-Apr-25	2369054	TMQA002	Mqatsheni Final	Fe (AE)	0.02	±5.4%	mg Fe/L
02-Apr-25	2369050	TMQA002	Mqatsheni Final	HPC 37*	0	±21%	cfu/mL
02-Apr-25	2369049	TMQA002	Mqatsheni Final	pH OS*	7.80	-	-
02-Apr-25	2369049	TMQA002	Mqatsheni Final	Temperature OS*	23.2	-	°C
02-Apr-25	2369052	TMQA002	Mqatsheni Final	Turbidity	0.5	±6.1%	NTU
02-Apr-25	2369065	TRV002	Riverside Final	Al (AE)	43.9	±7.6%	µg Al/L
02-Apr-25	2369060	TRV002	Riverside Final	Batch No.*	6246	-	-
02-Apr-25	2369060	TRV002	Riverside Final	Cl2 (F) OS*	1.03	-	mg Cl2/L
02-Apr-25	2369060	TRV002	Riverside Final	Cl2 (T) OS*	1.19	-	mg Cl2/L
02-Apr-25	2369061	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
02-Apr-25	2369061	TRV002	Riverside Final	Coliphages*	0	±8%	PFU/10ml
02-Apr-25	2369060	TRV002	Riverside Final	Coll Time OS*	08:00	-	-
02-Apr-25	2369064	TRV002	Riverside Final	Conductivity	22.2	±1.5%	mS/m
02-Apr-25	2369061	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
02-Apr-25	2369065	TRV002	Riverside Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
02-Apr-25	2369061	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
02-Apr-25	2369060	TRV002	Riverside Final	pH OS*	7.40	-	-
02-Apr-25	2369060	TRV002	Riverside Final	Temperature OS*	17.3	-	°C
02-Apr-25	2369063	TRV002	Riverside Final	Turbidity	0.5	±6.1%	NTU
02-Apr-25	2369076	TST002	St Appollinaris Final	Al (AE)	322	±7.6%	µg Al/L
02-Apr-25	2369071	TST002	St Appollinaris Final	Batch No.*	6246	-	-
02-Apr-25	2369071	TST002	St Appollinaris Final	Cl2 (F) OS*	0.60	-	mg Cl2/L
02-Apr-25	2369071	TST002	St Appollinaris Final	Cl2 (T) OS*	0.88	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

02-Apr-25	2369072	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
02-Apr-25	2369071	TST002	St Appollinaris Final	Coll Time OS*	09:25	-	-
02-Apr-25	2369075	TST002	St Appollinaris Final	Conductivity	7.34	±1.5%	mS/m
02-Apr-25	2369072	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
02-Apr-25	2369072	TST002	St Appollinaris Final	HPC 37*	20	±21%	cfu/mL
02-Apr-25	2369071	TST002	St Appollinaris Final	pH OS*	7.40	-	-
02-Apr-25	2369071	TST002	St Appollinaris Final	Temperature OS*	20.6	-	°C
02-Apr-25	2369074	TST002	St Appollinaris Final	Turbidity	6.2	±6.1%	NTU
02-Apr-25	2369087	TUN002	Underberg Final	Al (AE)	91.5	±7.6%	µg Al/L
02-Apr-25	2369082	TUN002	Underberg Final	Batch No.*	6240	-	-
02-Apr-25	2369082	TUN002	Underberg Final	Cl ₂ (F) OS*	0.84	-	mg Cl ₂ /L
02-Apr-25	2369082	TUN002	Underberg Final	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
02-Apr-25	2369083	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
02-Apr-25	2369082	TUN002	Underberg Final	Coll Time OS*	10:00	-	-
02-Apr-25	2369086	TUN002	Underberg Final	Conductivity	6.37	±1.5%	mS/m
02-Apr-25	2369083	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
02-Apr-25	2369083	TUN002	Underberg Final	HPC 37*	1	±21%	cfu/mL
02-Apr-25	2369082	TUN002	Underberg Final	pH OS*	7.60	-	-
02-Apr-25	2369082	TUN002	Underberg Final	Temperature OS*	23.1	-	°C
02-Apr-25	2369085	TUN002	Underberg Final	Turbidity	0.8	±6.1%	NTU
03-Apr-25	2369851	TMZ002	Umzimkhulu Final	Al (AE)	210	±7.6%	µg Al/L
03-Apr-25	2369846	TMZ002	Umzimkhulu Final	Batch No.*	6244	-	-
03-Apr-25	2369846	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	0.20	-	mg Cl ₂ /L
03-Apr-25	2369846	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	0.28	-	mg Cl ₂ /L
03-Apr-25	2369847	TMZ002	Umzimkhulu Final	Coliforms*	50	±15%	MPN/100mL
03-Apr-25	2369847	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
03-Apr-25	2369846	TMZ002	Umzimkhulu Final	Coll Time OS*	07:09	-	-
03-Apr-25	2369850	TMZ002	Umzimkhulu Final	Conductivity	6.69	±1.5%	mS/m
03-Apr-25	2369847	TMZ002	Umzimkhulu Final	E.coli*	3	±14%	MPN/100mL
03-Apr-25	2369847	TMZ002	Umzimkhulu Final	HPC 37*	36	±21%	cfu/mL
03-Apr-25	2369846	TMZ002	Umzimkhulu Final	pH OS*	7.40	-	-
03-Apr-25	2369846	TMZ002	Umzimkhulu Final	Temperature OS*	17.0	-	°C
03-Apr-25	2369849	TMZ002	Umzimkhulu Final	Turbidity	2.0	±6.1%	NTU
03-Apr-25	2369862	TNO002	Nokweja Final	Al (AE)	648	±7.6%	µg Al/L
03-Apr-25	2369857	TNO002	Nokweja Final	Batch No.*	6244	-	-
03-Apr-25	2369857	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.09	-	mg Cl ₂ /L
03-Apr-25	2369857	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.20	-	mg Cl ₂ /L
03-Apr-25	2369858	TNO002	Nokweja Final	Coliforms*	1	±15%	MPN/100mL
03-Apr-25	2369858	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
03-Apr-25	2369857	TNO002	Nokweja Final	Coll Time OS*	07:31	-	-
03-Apr-25	2369861	TNO002	Nokweja Final	Conductivity	8.32	±1.5%	mS/m
03-Apr-25	2369858	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

03-Apr-25	2369858	TNO002	Nokweja Final	HPC 37*	28	±21%	cfu/mL
03-Apr-25	2369857	TNO002	Nokweja Final	pH OS*	7.40	-	-
03-Apr-25	2369857	TNO002	Nokweja Final	Temperature OS*	18.2	-	°C
03-Apr-25	2369860	TNO002	Nokweja Final	Turbidity	5.8	±6.1%	NTU
03-Apr-25	2369873	TWA002	Washbank Final	Al (AE)	10787	±7.6%	µg Al/L
03-Apr-25	2369868	TWA002	Washbank Final	Batch No.*	6244	-	-
03-Apr-25	2369868	TWA002	Washbank Final	Cl2 (F) OS*	2.50	-	mg Cl2/L
03-Apr-25	2369868	TWA002	Washbank Final	Cl2 (T) OS*	3.50	-	mg Cl2/L
03-Apr-25	2369869	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
03-Apr-25	2369868	TWA002	Washbank Final	Coll Time OS*	06:40	-	-
03-Apr-25	2369872	TWA002	Washbank Final	Conductivity	11.5	±1.5%	mS/m
03-Apr-25	2369869	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
03-Apr-25	2369869	TWA002	Washbank Final	HPC 37*	2	±21%	cfu/mL
03-Apr-25	2369868	TWA002	Washbank Final	pH OS*	7.40	-	-
03-Apr-25	2369868	TWA002	Washbank Final	Temperature OS*	16.8	-	°C
03-Apr-25	2369871	TWA002	Washbank Final	Turbidity	17.4	±6.1%	NTU
04-Apr-25	2370104	TIB002	Ibisi Final	Al (AE)	308	±7.6%	µg Al/L
04-Apr-25	2370099	TIB002	Ibisi Final	Batch No.*	6240	-	-
04-Apr-25	2370099	TIB002	Ibisi Final	Cl2 (F) OS*	1.72	-	mg Cl2/L
04-Apr-25	2370099	TIB002	Ibisi Final	Cl2 (T) OS*	1.89	-	mg Cl2/L
04-Apr-25	2370100	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
04-Apr-25	2370100	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
04-Apr-25	2370099	TIB002	Ibisi Final	Coll Time OS*	07:31	-	-
04-Apr-25	2370103	TIB002	Ibisi Final	Conductivity	8.62	±1.5%	mS/m
04-Apr-25	2370100	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
04-Apr-25	2370100	TIB002	Ibisi Final	HPC 37*	24	±21%	cfu/mL
04-Apr-25	2370099	TIB002	Ibisi Final	pH OS*	7.50	-	-
04-Apr-25	2370099	TIB002	Ibisi Final	Temperature OS*	19.2	-	°C
04-Apr-25	2370102	TIB002	Ibisi Final	Turbidity	6.1	±6.1%	NTU
04-Apr-25	2370109	TRT002	Rietvlei Final	Batch No.*	6240	-	-
04-Apr-25	2370109	TRT002	Rietvlei Final	Cl2 (F) OS*	0.98	-	mg Cl2/L
04-Apr-25	2370109	TRT002	Rietvlei Final	Cl2 (T) OS*	1.14	-	mg Cl2/L
04-Apr-25	2370110	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
04-Apr-25	2370109	TRT002	Rietvlei Final	Coll Time OS*	06:56	-	-
04-Apr-25	2370113	TRT002	Rietvlei Final	Conductivity	17.4	±1.5%	mS/m
04-Apr-25	2370110	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
04-Apr-25	2370110	TRT002	Rietvlei Final	HPC 37*	28	±21%	cfu/mL
04-Apr-25	2370109	TRT002	Rietvlei Final	pH OS*	7.60	-	-
04-Apr-25	2370109	TRT002	Rietvlei Final	Temperature OS*	18.7	-	°C
04-Apr-25	2370112	TRT002	Rietvlei Final	Turbidity	2.6	±6.1%	NTU
07-Apr-25	2373141	TFR002	Franklin Final	Al (AE)	313	±7.6%	µg Al/L
07-Apr-25	2373136	TFR002	Franklin Final	Batch No.*	6240	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

07-Apr-25	2373136	TFR002	Franklin Final	Cl2 (F) OS*	0.21	-	mg Cl2/L
07-Apr-25	2373136	TFR002	Franklin Final	Cl2 (T) OS*	0.34	-	mg Cl2/L
07-Apr-25	2373137	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
07-Apr-25	2373137	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
07-Apr-25	2373136	TFR002	Franklin Final	Coll Time OS*	08:44	-	-
07-Apr-25	2373139	TFR002	Franklin Final	Colour	<1.00	±6.5%	mg Pt-Co/L
07-Apr-25	2373140	TFR002	Franklin Final	Conductivity	16.3	±1.5%	mS/m
07-Apr-25	2373137	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
07-Apr-25	2373141	TFR002	Franklin Final	Fe (AE)	0.18	±5.4%	mg Fe/L
07-Apr-25	2373137	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
07-Apr-25	2373141	TFR002	Franklin Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
07-Apr-25	2373136	TFR002	Franklin Final	pH OS*	7.20	-	-
07-Apr-25	2373136	TFR002	Franklin Final	Temperature OS*	16.6	-	°C
07-Apr-25	2373139	TFR002	Franklin Final	Turbidity	3.2	±6.1%	NTU
07-Apr-25	2373142	TFR003	Franklin Police Station Retic	Batch No.*	6246	-	-
07-Apr-25	2373142	TFR003	Franklin Police Station Retic	Cl2 (F) OS*	0.30	-	mg Cl2/L
07-Apr-25	2373142	TFR003	Franklin Police Station Retic	Cl2 (T) OS*	0.40	-	mg Cl2/L
07-Apr-25	2373143	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
07-Apr-25	2373142	TFR003	Franklin Police Station Retic	Coll Time OS*	08:58	-	-
07-Apr-25	2373145	TFR003	Franklin Police Station Retic	Colour	1.10	±6.5%	mg Pt-Co/L
07-Apr-25	2373146	TFR003	Franklin Police Station Retic	Conductivity	15.6	±1.5%	mS/m
07-Apr-25	2373143	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
07-Apr-25	2373143	TFR003	Franklin Police Station Retic	HPC 37*	2	±21%	cfu/mL
07-Apr-25	2373145	TFR003	Franklin Police Station Retic	Odour*	Nil	-	-
07-Apr-25	2373142	TFR003	Franklin Police Station Retic	pH OS*	7.20	-	-
07-Apr-25	2373142	TFR003	Franklin Police Station Retic	Temperature OS*	17.5	-	°C
07-Apr-25	2373145	TFR003	Franklin Police Station Retic	Turbidity	0.5	±6.1%	NTU
07-Apr-25	2373177	TKK002	Kokstad Final	Al (AE)	32.4	±7.6%	µg Al/L
07-Apr-25	2373172	TKK002	Kokstad Final	Batch No.*	6246	-	-
07-Apr-25	2373172	TKK002	Kokstad Final	Cl2 (F) OS*	2.20	-	mg Cl2/L
07-Apr-25	2373172	TKK002	Kokstad Final	Cl2 (T) OS*	3.30	-	mg Cl2/L
07-Apr-25	2373173	TKK002	Kokstad Final	Coliforms*	1	±15%	MPN/100mL
07-Apr-25	2373173	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
07-Apr-25	2373172	TKK002	Kokstad Final	Coll Time OS*	09:20	-	-
07-Apr-25	2373175	TKK002	Kokstad Final	Colour	1.30	±6.5%	mg Pt-Co/L
07-Apr-25	2373176	TKK002	Kokstad Final	Conductivity	11.9	±1.5%	mS/m
07-Apr-25	2373173	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

07-Apr-25	2373177	TKK002	Kokstad Final	Fe (AE)	0.03	±5.4%	mg Fe/L
07-Apr-25	2373173	TKK002	Kokstad Final	HPC 37*	0	±21%	cfu/mL
07-Apr-25	2373175	TKK002	Kokstad Final	Odour*	Nil	-	-
07-Apr-25	2373172	TKK002	Kokstad Final	pH OS*	7.40	-	-
07-Apr-25	2373175	TKK002	Kokstad Final	Taste*	Nil	-	-
07-Apr-25	2373172	TKK002	Kokstad Final	Temperature OS*	22.2	-	°C
07-Apr-25	2373175	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
07-Apr-25	2373187	TKK006	Kokstad Bongweni Correctional Serv Retic	Batch No.*	6246	-	-
07-Apr-25	2373187	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (F) OS*	1.19	-	mg Cl2/L
07-Apr-25	2373187	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (T) OS*	1.85	-	mg Cl2/L
07-Apr-25	2373188	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
07-Apr-25	2373187	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	09:10	-	-
07-Apr-25	2373190	TKK006	Kokstad Bongweni Correctional Serv Retic	Colour	1.50	±6.5%	mg Pt-Co/L
07-Apr-25	2373188	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
07-Apr-25	2373188	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	cfu/mL
07-Apr-25	2373190	TKK006	Kokstad Bongweni Correctional Serv Retic	Odour*	Nil	-	-
07-Apr-25	2373187	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.50	-	-
07-Apr-25	2373190	TKK006	Kokstad Bongweni Correctional Serv Retic	Taste*	Nil	-	-
07-Apr-25	2373187	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	23.4	-	°C
07-Apr-25	2373190	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.3	±6.1%	NTU
07-Apr-25	2373191	TKK007	Kokstad Shayamoya Reticulation	Batch No.*	6246	-	-
07-Apr-25	2373191	TKK007	Kokstad Shayamoya Reticulation	Cl2 (F) OS*	0.35	-	mg Cl2/L
07-Apr-25	2373191	TKK007	Kokstad Shayamoya Reticulation	Cl2 (T) OS*	0.58	-	mg Cl2/L
07-Apr-25	2373192	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
07-Apr-25	2373191	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	10:00	-	-
07-Apr-25	2373194	TKK007	Kokstad Shayamoya Reticulation	Colour	2.00	±6.5%	mg Pt-Co/L
07-Apr-25	2373192	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
07-Apr-25	2373192	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	2	±21%	cfu/mL
07-Apr-25	2373194	TKK007	Kokstad Shayamoya Reticulation	Odour*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

07-Apr-25	2373191	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.30	-	-
07-Apr-25	2373194	TKK007	Kokstad Shayamoya Reticulation	Taste*	Nil	-	-
07-Apr-25	2373191	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	23.3	-	°C
07-Apr-25	2373194	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.5	±6.1%	NTU
07-Apr-25	2373195	TKK009	Kokstad Farm Fresh Produce Market	Batch No.*	6246	-	-
07-Apr-25	2373195	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (F) OS*	0.65	-	mg Cl ₂ /L
07-Apr-25	2373195	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
07-Apr-25	2373196	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
07-Apr-25	2373195	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	10:30	-	-
07-Apr-25	2373198	TKK009	Kokstad Farm Fresh Produce Market	Colour	<1.00	±6.5%	mg Pt-Co/L
07-Apr-25	2373196	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
07-Apr-25	2373196	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	0	±21%	cfu/mL
07-Apr-25	2373198	TKK009	Kokstad Farm Fresh Produce Market	Odour*	Nil	-	-
07-Apr-25	2373195	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.50	-	-
07-Apr-25	2373198	TKK009	Kokstad Farm Fresh Produce Market	Taste*	Nil	-	-
07-Apr-25	2373195	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	24.1	-	°C
07-Apr-25	2373198	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.3	±6.1%	NTU
07-Apr-25	2373199	TKK012	Kokstad FET College Reticulation	Batch No.*	6246	-	-
07-Apr-25	2373199	TKK012	Kokstad FET College Reticulation	Cl ₂ (F) OS*	0.15	-	mg Cl ₂ /L
07-Apr-25	2373199	TKK012	Kokstad FET College Reticulation	Cl ₂ (T) OS*	0.28	-	mg Cl ₂ /L
07-Apr-25	2373200	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
07-Apr-25	2373199	TKK012	Kokstad FET College Reticulation	Coll Time OS*	08:30	-	-
07-Apr-25	2373202	TKK012	Kokstad FET College Reticulation	Colour	1.30	±6.5%	mg Pt-Co/L
07-Apr-25	2373203	TKK012	Kokstad FET College Reticulation	Conductivity	11.4	±1.5%	mS/m
07-Apr-25	2373200	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
07-Apr-25	2373200	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	cfu/mL
07-Apr-25	2373199	TKK012	Kokstad FET College Reticulation	pH OS*	7.40	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

07-Apr-25	2373199	TKK012	Kokstad FET College Reticulation	Temperature OS*	20.1	-	°C
07-Apr-25	2373202	TKK012	Kokstad FET College Reticulation	Turbidity	0.3	±6.1%	NTU
07-Apr-25	2373231	TNJU002	KwaNjunga Final	Al (AE)	89.5	±7.6%	µg Al/L
07-Apr-25	2373226	TNJU002	KwaNjunga Final	Batch No.*	6240	-	-
07-Apr-25	2373226	TNJU002	KwaNjunga Final	Cl2 (F) OS*	0.74	-	mg Cl2/L
07-Apr-25	2373226	TNJU002	KwaNjunga Final	Cl2 (T) OS*	0.90	-	mg Cl2/L
07-Apr-25	2373227	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
07-Apr-25	2373226	TNJU002	KwaNjunga Final	Coll Time OS*	07:42	-	-
07-Apr-25	2373230	TNJU002	KwaNjunga Final	Conductivity	15.9	±1.5%	mS/m
07-Apr-25	2373227	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
07-Apr-25	2373231	TNJU002	KwaNjunga Final	Fe (AE)	0.02	±5.4%	mg Fe/L
07-Apr-25	2373227	TNJU002	KwaNjunga Final	HPC 37*	1	±21%	cfu/mL
07-Apr-25	2373231	TNJU002	KwaNjunga Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
07-Apr-25	2373229	TNJU002	KwaNjunga Final	Odour*	Nil	-	-
07-Apr-25	2373226	TNJU002	KwaNjunga Final	pH OS*	7.20	-	-
07-Apr-25	2373229	TNJU002	KwaNjunga Final	Taste*	Nil	-	-
07-Apr-25	2373226	TNJU002	KwaNjunga Final	Temperature OS*	17.9	-	°C
07-Apr-25	2373229	TNJU002	KwaNjunga Final	Turbidity	0.6	±6.1%	NTU
07-Apr-25	2373232	TNJU003	KwaNjunga Reticulation	Batch No.*	6240	-	-
07-Apr-25	2373232	TNJU003	KwaNjunga Reticulation	Cl2 (F) OS*	0.36	-	mg Cl2/L
07-Apr-25	2373232	TNJU003	KwaNjunga Reticulation	Cl2 (T) OS*	0.47	-	mg Cl2/L
07-Apr-25	2373233	TNJU003	KwaNjunga Reticulation	Coliforms*	25	±15%	MPN/100mL
07-Apr-25	2373232	TNJU003	KwaNjunga Reticulation	Coll Time OS*	06:40	-	-
07-Apr-25	2373235	TNJU003	KwaNjunga Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
07-Apr-25	2373236	TNJU003	KwaNjunga Reticulation	Conductivity	15.7	±1.5%	mS/m
07-Apr-25	2373233	TNJU003	KwaNjunga Reticulation	E.coli*	0	±14%	MPN/100mL
07-Apr-25	2373233	TNJU003	KwaNjunga Reticulation	HPC 37*	109	±21%	cfu/mL
07-Apr-25	2373235	TNJU003	KwaNjunga Reticulation	Odour*	Nil	-	-
07-Apr-25	2373232	TNJU003	KwaNjunga Reticulation	pH OS*	7.50	-	-
07-Apr-25	2373232	TNJU003	KwaNjunga Reticulation	Temperature OS*	20.2	-	°C
07-Apr-25	2373235	TNJU003	KwaNjunga Reticulation	Turbidity	0.7	±6.1%	NTU
08-Apr-25	2373985	TJO001	Jolivet RRT frn Vulamehlo	Batch No.*	6246	-	-
08-Apr-25	2373985	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (F) OS*	0.60	-	mg Cl2/L
08-Apr-25	2373985	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (T) OS*	0.80	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

08-Apr-25	2373986	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
08-Apr-25	2373985	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	10h55	-	-
08-Apr-25	2373988	TJO001	Jolivet RRT frn Vulamehlo	Colour	1.70	±6.5%	mg Pt-Co/L
08-Apr-25	2373989	TJO001	Jolivet RRT frn Vulamehlo	Conductivity	16.1	±1.5%	mS/m
08-Apr-25	2373986	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
08-Apr-25	2373986	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	6	±21%	cfu/mL
08-Apr-25	2373988	TJO001	Jolivet RRT frn Vulamehlo	Odour*	Nil	-	-
08-Apr-25	2373985	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	7.60	-	-
08-Apr-25	2373985	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	18.8	-	°C
08-Apr-25	2373988	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	3.5	±6.1%	NTU
08-Apr-25	2374073	TSQ002	Esiqanduleni Final	Al (AE)	316	±7.6%	µg Al/L
08-Apr-25	2374068	TSQ002	Esiqanduleni Final	Batch No.*	6246	-	-
08-Apr-25	2374068	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	0.98	-	mg Cl2/L
08-Apr-25	2374068	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.16	-	mg Cl2/L
08-Apr-25	2374069	TSQ002	Esiqanduleni Final	Coliforms*	9	±15%	MPN/100mL
08-Apr-25	2374068	TSQ002	Esiqanduleni Final	Coll Time OS*	08:30	-	-
08-Apr-25	2374071	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
08-Apr-25	2374072	TSQ002	Esiqanduleni Final	Conductivity	7.87	±1.5%	mS/m
08-Apr-25	2374069	TSQ002	Esiqanduleni Final	E.coli*	1	±14%	MPN/100mL
08-Apr-25	2374069	TSQ002	Esiqanduleni Final	HPC 37*	22	±21%	cfu/mL
08-Apr-25	2374071	TSQ002	Esiqanduleni Final	Odour*	Nil	-	-
08-Apr-25	2374068	TSQ002	Esiqanduleni Final	pH OS*	7.40	-	-
08-Apr-25	2374068	TSQ002	Esiqanduleni Final	Temperature OS*	21.2	-	°C
08-Apr-25	2374071	TSQ002	Esiqanduleni Final	Turbidity	3.4	±6.1%	NTU
09-Apr-25	2374667	TBU002	Bulwer Final	Batch No.*	6246	-	-
09-Apr-25	2374667	TBU002	Bulwer Final	Cl2 (F) OS*	2.13	-	mg Cl2/L
09-Apr-25	2374667	TBU002	Bulwer Final	Cl2 (T) OS*	2.40	-	mg Cl2/L
09-Apr-25	2374668	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374667	TBU002	Bulwer Final	Coll Time OS*	10:09	-	-
09-Apr-25	2374670	TBU002	Bulwer Final	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374671	TBU002	Bulwer Final	Conductivity	4.59	±1.5%	mS/m
09-Apr-25	2374668	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374668	TBU002	Bulwer Final	HPC 37*	10	±21%	cfu/mL
09-Apr-25	2374670	TBU002	Bulwer Final	Odour*	Nil	-	-
09-Apr-25	2374667	TBU002	Bulwer Final	pH OS*	7.30	-	-
09-Apr-25	2374667	TBU002	Bulwer Final	Temperature OS*	26.2	-	°C
09-Apr-25	2374670	TBU002	Bulwer Final	Turbidity	5.5	±6.1%	NTU
09-Apr-25	2374672	TBU005	Bulwer Mountain Park Hotel Retic	Batch No.*	6246	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

09-Apr-25	2374672	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (F) OS*	1.25	-	mg Cl2/L
09-Apr-25	2374672	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (T) OS*	1.34	-	mg Cl2/L
09-Apr-25	2374673	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374672	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	10:40	-	-
09-Apr-25	2374675	TBU005	Bulwer Mountain Park Hotel Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374676	TBU005	Bulwer Mountain Park Hotel Retic	Conductivity	4.87	±1.5%	mS/m
09-Apr-25	2374673	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374673	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	0	±21%	cfu/mL
09-Apr-25	2374672	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.40	-	-
09-Apr-25	2374672	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	21.2	-	°C
09-Apr-25	2374675	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	4.9	±6.1%	NTU
09-Apr-25	2374687	TCR002	Creighton Final	Al (AE)	182	±7.6%	µg Al/L
09-Apr-25	2374682	TCR002	Creighton Final	Batch No.*	6246	-	-
09-Apr-25	2374682	TCR002	Creighton Final	Cl2 (F) OS*	0.78	-	mg Cl2/L
09-Apr-25	2374682	TCR002	Creighton Final	Cl2 (T) OS*	0.89	-	mg Cl2/L
09-Apr-25	2374683	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374682	TCR002	Creighton Final	Coll Time OS*	08:06	-	-
09-Apr-25	2374686	TCR002	Creighton Final	Conductivity	9.22	±1.5%	mS/m
09-Apr-25	2374683	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374683	TCR002	Creighton Final	HPC 37*	0	±21%	cfu/mL
09-Apr-25	2374682	TCR002	Creighton Final	pH OS*	7.40	-	-
09-Apr-25	2374682	TCR002	Creighton Final	Temperature OS*	20.3	-	°C
09-Apr-25	2374685	TCR002	Creighton Final	Turbidity	2.2	±6.1%	NTU
09-Apr-25	2374688	TCR004	Creighton Madondo Cottages	Batch No.*	6246	-	-
09-Apr-25	2374688	TCR004	Creighton Madondo Cottages	Cl2 (F) OS*	0.45	-	mg Cl2/L
09-Apr-25	2374688	TCR004	Creighton Madondo Cottages	Cl2 (T) OS*	0.60	-	mg Cl2/L
09-Apr-25	2374689	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374688	TCR004	Creighton Madondo Cottages	Coll Time OS*	07:50	-	-
09-Apr-25	2374691	TCR004	Creighton Madondo Cottages	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374692	TCR004	Creighton Madondo Cottages	Conductivity	10.8	±1.5%	mS/m
09-Apr-25	2374689	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374689	TCR004	Creighton Madondo Cottages	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

09-Apr-25	2374688	TCR004	Creighton Madondo Cottages	pH OS*	7.20	-	-
09-Apr-25	2374688	TCR004	Creighton Madondo Cottages	Temperature OS*	19.8	-	°C
09-Apr-25	2374691	TCR004	Creighton Madondo Cottages	Turbidity	1.2	±6.1%	NTU
09-Apr-25	2374702	THL002	Hlanganani Final	Batch No.*	6246	-	-
09-Apr-25	2374702	THL002	Hlanganani Final	Cl2 (F) OS*	0.30	-	mg Cl2/L
09-Apr-25	2374702	THL002	Hlanganani Final	Cl2 (T) OS*	0.41	-	mg Cl2/L
09-Apr-25	2374703	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374702	THL002	Hlanganani Final	Coll Time OS*	11:30	-	-
09-Apr-25	2374705	THL002	Hlanganani Final	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374706	THL002	Hlanganani Final	Conductivity	7.58	±1.5%	mS/m
09-Apr-25	2374703	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374703	THL002	Hlanganani Final	HPC 37*	3	±21%	cfu/mL
09-Apr-25	2374705	THL002	Hlanganani Final	Odour*	Nil	-	-
09-Apr-25	2374702	THL002	Hlanganani Final	pH OS*	7.50	-	-
09-Apr-25	2374705	THL002	Hlanganani Final	Taste*	Nil	-	-
09-Apr-25	2374702	THL002	Hlanganani Final	Temperature OS*	19.7	-	°C
09-Apr-25	2374705	THL002	Hlanganani Final	Turbidity	0.3	±6.1%	NTU
09-Apr-25	2374707	THL003	Hlanganani Clinic Reticulation	Batch No.*	6246	-	-
09-Apr-25	2374707	THL003	Hlanganani Clinic Reticulation	Cl2 (F) OS*	0.86	-	mg Cl2/L
09-Apr-25	2374707	THL003	Hlanganani Clinic Reticulation	Cl2 (T) OS*	1.02	-	mg Cl2/L
09-Apr-25	2374708	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374707	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	11:40	-	-
09-Apr-25	2374710	THL003	Hlanganani Clinic Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374711	THL003	Hlanganani Clinic Reticulation	Conductivity	7.24	±1.5%	mS/m
09-Apr-25	2374708	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374708	THL003	Hlanganani Clinic Reticulation	HPC 37*	10	±21%	cfu/mL
09-Apr-25	2374707	THL003	Hlanganani Clinic Reticulation	pH OS*	7.60	-	-
09-Apr-25	2374707	THL003	Hlanganani Clinic Reticulation	Temperature OS*	19.2	-	°C
09-Apr-25	2374710	THL003	Hlanganani Clinic Reticulation	Turbidity	0.4	±6.1%	NTU
09-Apr-25	2374727	TMAN002	Mangwaneni Final	Batch No.*	6246	-	-
09-Apr-25	2374727	TMAN002	Mangwaneni Final	Cl2 (F) OS*	0.12	-	mg Cl2/L
09-Apr-25	2374727	TMAN002	Mangwaneni Final	Cl2 (T) OS*	0.18	-	mg Cl2/L
09-Apr-25	2374728	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374727	TMAN002	Mangwaneni Final	Coll Time OS*	11:06	-	-
09-Apr-25	2374730	TMAN002	Mangwaneni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374731	TMAN002	Mangwaneni Final	Conductivity	9.88	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

09-Apr-25	2374728	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374728	TMAN002	Mangwaneni Final	HPC 37*	0	±21%	cfu/mL
09-Apr-25	2374730	TMAN002	Mangwaneni Final	Odour*	Nil	-	-
09-Apr-25	2374727	TMAN002	Mangwaneni Final	pH OS*	7.60	-	-
09-Apr-25	2374727	TMAN002	Mangwaneni Final	Temperature OS*	22.1	-	°C
09-Apr-25	2374730	TMAN002	Mangwaneni Final	Turbidity	0.9	±6.1%	NTU
09-Apr-25	2374736	TMQA002	Mqatsheni Final	Batch No.*	6246	-	-
09-Apr-25	2374736	TMQA002	Mqatsheni Final	Cl ₂ (F) OS*	0.71	-	mg Cl ₂ /L
09-Apr-25	2374736	TMQA002	Mqatsheni Final	Cl ₂ (T) OS*	0.92	-	mg Cl ₂ /L
09-Apr-25	2374737	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374736	TMQA002	Mqatsheni Final	Coll Time OS*	08:38	-	-
09-Apr-25	2374739	TMQA002	Mqatsheni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374740	TMQA002	Mqatsheni Final	Conductivity	24.6	±1.5%	mS/m
09-Apr-25	2374737	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374737	TMQA002	Mqatsheni Final	HPC 37*	0	±21%	cfu/mL
09-Apr-25	2374739	TMQA002	Mqatsheni Final	Odour*	Nil	-	-
09-Apr-25	2374736	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
09-Apr-25	2374739	TMQA002	Mqatsheni Final	Taste*	Nil	-	-
09-Apr-25	2374736	TMQA002	Mqatsheni Final	Temperature OS*	21.3	-	°C
09-Apr-25	2374739	TMQA002	Mqatsheni Final	Turbidity	0.5	±6.1%	NTU
09-Apr-25	2374741	TMQA003	Mqatsheni Reticulation	Batch No.*	6246	-	-
09-Apr-25	2374741	TMQA003	Mqatsheni Reticulation	Cl ₂ (F) OS*	1.15	-	mg Cl ₂ /L
09-Apr-25	2374741	TMQA003	Mqatsheni Reticulation	Cl ₂ (T) OS*	1.26	-	mg Cl ₂ /L
09-Apr-25	2374742	TMQA003	Mqatsheni Reticulation	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374741	TMQA003	Mqatsheni Reticulation	Coll Time OS*	08:00	-	-
09-Apr-25	2374744	TMQA003	Mqatsheni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374745	TMQA003	Mqatsheni Reticulation	Conductivity	26.4	±1.5%	mS/m
09-Apr-25	2374742	TMQA003	Mqatsheni Reticulation	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374742	TMQA003	Mqatsheni Reticulation	HPC 37*	0	±21%	cfu/mL
09-Apr-25	2374741	TMQA003	Mqatsheni Reticulation	pH OS*	8.90	-	-
09-Apr-25	2374741	TMQA003	Mqatsheni Reticulation	Temperature OS*	18.9	-	°C
09-Apr-25	2374744	TMQA003	Mqatsheni Reticulation	Turbidity	1.4	±6.1%	NTU
09-Apr-25	2374756	TRV002	Riverside Final	Al (AE)	134	±7.6%	µg Al/L
09-Apr-25	2374751	TRV002	Riverside Final	Batch No.*	6246	-	-
09-Apr-25	2374751	TRV002	Riverside Final	Cl ₂ (F) OS*	1.09	-	mg Cl ₂ /L
09-Apr-25	2374751	TRV002	Riverside Final	Cl ₂ (T) OS*	1.20	-	mg Cl ₂ /L
09-Apr-25	2374752	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374752	TRV002	Riverside Final	Coliphages*	0	±8%	PFU/10ml
09-Apr-25	2374751	TRV002	Riverside Final	Coll Time OS*	08:56	-	-
09-Apr-25	2374754	TRV002	Riverside Final	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374755	TRV002	Riverside Final	Conductivity	17.2	±1.5%	mS/m
09-Apr-25	2374752	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

09-Apr-25	2374752	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
09-Apr-25	2374754	TRV002	Riverside Final	Odour*	Nil	-	-
09-Apr-25	2374751	TRV002	Riverside Final	pH OS*	7.40	-	-
09-Apr-25	2374751	TRV002	Riverside Final	Temperature OS*	22.7	-	°C
09-Apr-25	2374754	TRV002	Riverside Final	Turbidity	0.8	±6.1%	NTU
09-Apr-25	2374757	TRV003	Riverside Reticulation	Batch No.*	6246	-	-
09-Apr-25	2374757	TRV003	Riverside Reticulation	Cl2 (F) OS*	1.02	-	mg Cl2/L
09-Apr-25	2374757	TRV003	Riverside Reticulation	Cl2 (T) OS*	1.15	-	mg Cl2/L
09-Apr-25	2374758	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374757	TRV003	Riverside Reticulation	Coll Time OS*	08:49	-	-
09-Apr-25	2374760	TRV003	Riverside Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Apr-25	2374758	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374758	TRV003	Riverside Reticulation	HPC 37*	0	±21%	cfu/mL
09-Apr-25	2374760	TRV003	Riverside Reticulation	Odour*	Nil	-	-
09-Apr-25	2374757	TRV003	Riverside Reticulation	pH OS*	7.50	-	-
09-Apr-25	2374757	TRV003	Riverside Reticulation	Temperature OS*	20.3	-	°C
09-Apr-25	2374760	TRV003	Riverside Reticulation	Turbidity	2.0	±6.1%	NTU
09-Apr-25	2374771	TST002	St Appollinaris Final	Al (AE)	552	±7.6%	µg Al/L
09-Apr-25	2374766	TST002	St Appollinaris Final	Batch No.*	6246	-	-
09-Apr-25	2374766	TST002	St Appollinaris Final	Cl2 (F) OS*	0.15	-	mg Cl2/L
09-Apr-25	2374766	TST002	St Appollinaris Final	Cl2 (T) OS*	0.20	-	mg Cl2/L
09-Apr-25	2374767	TST002	St Appollinaris Final	Coliforms*	>201	±15%	MPN/100mL
09-Apr-25	2374766	TST002	St Appollinaris Final	Coll Time OS*	09:36	-	-
09-Apr-25	2374769	TST002	St Appollinaris Final	Colour	4.50	±6.5%	mg Pt-Co/L
09-Apr-25	2374770	TST002	St Appollinaris Final	Conductivity	7.22	±1.5%	mS/m
09-Apr-25	2374767	TST002	St Appollinaris Final	E.coli*	1	±14%	MPN/100mL
09-Apr-25	2374767	TST002	St Appollinaris Final	HPC 37*	302	±21%	cfu/mL
09-Apr-25	2374769	TST002	St Appollinaris Final	Odour*	Nil	-	-
09-Apr-25	2374766	TST002	St Appollinaris Final	pH OS*	7.60	-	-
09-Apr-25	2374766	TST002	St Appollinaris Final	Temperature OS*	24.2	-	°C
09-Apr-25	2374769	TST002	St Appollinaris Final	Turbidity	4.9	±6.1%	NTU
09-Apr-25	2374782	TUN002	Underberg Final	Al (AE)	84.4	±7.6%	µg Al/L
09-Apr-25	2374777	TUN002	Underberg Final	Batch No.*	6246	-	-
09-Apr-25	2374777	TUN002	Underberg Final	Cl2 (F) OS*	0.56	-	mg Cl2/L
09-Apr-25	2374777	TUN002	Underberg Final	Cl2 (T) OS*	0.72	-	mg Cl2/L
09-Apr-25	2374778	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
09-Apr-25	2374777	TUN002	Underberg Final	Coll Time OS*	10:44	-	-
09-Apr-25	2374780	TUN002	Underberg Final	Colour	1.10	±6.5%	mg Pt-Co/L
09-Apr-25	2374781	TUN002	Underberg Final	Conductivity	6.31	±1.5%	mS/m
09-Apr-25	2374778	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
09-Apr-25	2374778	TUN002	Underberg Final	HPC 37*	0	±21%	cfu/mL
09-Apr-25	2374780	TUN002	Underberg Final	Odour*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

09-Apr-25	2374777	TUN002	Underberg Final	pH OS*	7.20	-	-
09-Apr-25	2374777	TUN002	Underberg Final	Temperature OS*	20.5	-	°C
09-Apr-25	2374780	TUN002	Underberg Final	Turbidity	1.1	±6.1%	NTU
10-Apr-25	2375542	TMZ002	Umzimkhulu Final	Al (AE)	313	±7.6%	µg Al/L
10-Apr-25	2375537	TMZ002	Umzimkhulu Final	Batch No.*	6246	-	-
10-Apr-25	2375537	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
10-Apr-25	2375537	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.11	-	mg Cl ₂ /L
10-Apr-25	2375538	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
10-Apr-25	2375538	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
10-Apr-25	2375537	TMZ002	Umzimkhulu Final	Coll Time OS*	07:40	-	-
10-Apr-25	2375540	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Apr-25	2375541	TMZ002	Umzimkhulu Final	Conductivity	8.03	±1.5%	mS/m
10-Apr-25	2375538	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
10-Apr-25	2375542	TMZ002	Umzimkhulu Final	Fe (AE)	0.16	±5.4%	mg Fe/L
10-Apr-25	2375538	TMZ002	Umzimkhulu Final	HPC 37*	5	±21%	cfu/mL
10-Apr-25	2375540	TMZ002	Umzimkhulu Final	Odour*	Nil	-	-
10-Apr-25	2375537	TMZ002	Umzimkhulu Final	pH OS*	7.50	-	-
10-Apr-25	2375537	TMZ002	Umzimkhulu Final	Temperature OS*	20.1	-	°C
10-Apr-25	2375540	TMZ002	Umzimkhulu Final	Turbidity	3.6	±6.1%	NTU
10-Apr-25	2375543	TMZ004	Umzikhulu Informal Settlement Retic	Batch No.*	6246	-	-
10-Apr-25	2375543	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (F) OS*	0.74	-	mg Cl ₂ /L
10-Apr-25	2375543	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
10-Apr-25	2375544	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	0	±15%	MPN/100mL
10-Apr-25	2375543	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	08:00	-	-
10-Apr-25	2375544	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
10-Apr-25	2375544	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	1	±21%	cfu/mL
10-Apr-25	2375543	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.50	-	-
10-Apr-25	2375543	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	20.4	-	°C
10-Apr-25	2375546	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	3.0	±6.1%	NTU
10-Apr-25	2375547	TMZ005	Umzimkhulu Local Municipality Offices	Batch No.*	6246	-	-
10-Apr-25	2375547	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
10-Apr-25	2375547	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (T) OS*	1.09	-	mg Cl ₂ /L
10-Apr-25	2375548	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
10-Apr-25	2375547	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	07:50	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Apr-25	2375548	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
10-Apr-25	2375548	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	0	±21%	cfu/mL
10-Apr-25	2375547	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.50	-	-
10-Apr-25	2375547	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	20.4	-	°C
10-Apr-25	2375550	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	3.4	±6.1%	NTU
10-Apr-25	2375551	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Batch No.*	6246	-	-
10-Apr-25	2375551	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl2 (F) OS*	0.37	-	mg Cl2/L
10-Apr-25	2375551	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl2 (T) OS*	0.86	-	mg Cl2/L
10-Apr-25	2375552	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coliforms*	>201	±15%	MPN/100mL
10-Apr-25	2375551	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coll Time OS*	08:20	-	-
10-Apr-25	2375552	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	E.coli*	45	±14%	MPN/100mL
10-Apr-25	2375552	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	HPC 37*	175	±21%	cfu/mL
10-Apr-25	2375551	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	7.40	-	-
10-Apr-25	2375551	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	19.5	-	°C
10-Apr-25	2375554	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	1.3	±6.1%	NTU
10-Apr-25	2375555	TMZ007	Umzimkhulu Local FET College	Batch No.*	6246	-	-
10-Apr-25	2375555	TMZ007	Umzimkhulu Local FET College	Cl2 (F) OS*	0.25	-	mg Cl2/L
10-Apr-25	2375555	TMZ007	Umzimkhulu Local FET College	Cl2 (T) OS*	0.34	-	mg Cl2/L
10-Apr-25	2375556	TMZ007	Umzimkhulu Local FET College	Coliforms*	0	±15%	MPN/100mL
10-Apr-25	2375555	TMZ007	Umzimkhulu Local FET College	Coll Time OS*	08:40	-	-
10-Apr-25	2375556	TMZ007	Umzimkhulu Local FET College	E.coli*	0	±14%	MPN/100mL
10-Apr-25	2375556	TMZ007	Umzimkhulu Local FET College	HPC 37*	22	±21%	cfu/mL
10-Apr-25	2375555	TMZ007	Umzimkhulu Local FET College	pH OS*	7.50	-	-
10-Apr-25	2375555	TMZ007	Umzimkhulu Local FET College	Temperature OS*	18.6	-	°C
10-Apr-25	2375558	TMZ007	Umzimkhulu Local FET College	Turbidity	11.9	±6.1%	NTU
10-Apr-25	2375569	TNO002	Nokweja Final	AI (AE)	480	±7.6%	µg AI/L
10-Apr-25	2375564	TNO002	Nokweja Final	Batch No.*	6246	-	-
10-Apr-25	2375564	TNO002	Nokweja Final	Cl2 (F) OS*	0.84	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Apr-25	2375564	TNO002	Nokweja Final	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
10-Apr-25	2375565	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
10-Apr-25	2375565	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
10-Apr-25	2375564	TNO002	Nokweja Final	Coll Time OS*	07:30	-	-
10-Apr-25	2375567	TNO002	Nokweja Final	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Apr-25	2375568	TNO002	Nokweja Final	Conductivity	7.64	±1.5%	mS/m
10-Apr-25	2375565	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
10-Apr-25	2375565	TNO002	Nokweja Final	HPC 37*	27	±21%	cfu/mL
10-Apr-25	2375567	TNO002	Nokweja Final	Odour*	Nil	-	-
10-Apr-25	2375564	TNO002	Nokweja Final	pH OS*	7.60	-	-
10-Apr-25	2375564	TNO002	Nokweja Final	Temperature OS*	19.2	-	°C
10-Apr-25	2375567	TNO002	Nokweja Final	Turbidity	3.3	±6.1%	NTU
10-Apr-25	2375588	TWA002	Washbank Final	Al (AE)	943	±7.6%	µg Al/L
10-Apr-25	2375583	TWA002	Washbank Final	Batch No.*	6246	-	-
10-Apr-25	2375583	TWA002	Washbank Final	Cl ₂ (F) OS*	1.25	-	mg Cl ₂ /L
10-Apr-25	2375583	TWA002	Washbank Final	Cl ₂ (T) OS*	1.30	-	mg Cl ₂ /L
10-Apr-25	2375584	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
10-Apr-25	2375583	TWA002	Washbank Final	Coll Time OS*	06:27	-	-
10-Apr-25	2375586	TWA002	Washbank Final	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Apr-25	2375587	TWA002	Washbank Final	Conductivity	7.86	±1.5%	mS/m
10-Apr-25	2375584	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
10-Apr-25	2375584	TWA002	Washbank Final	HPC 37*	1	±21%	cfu/mL
10-Apr-25	2375586	TWA002	Washbank Final	Odour*	Nil	-	-
10-Apr-25	2375583	TWA002	Washbank Final	pH OS*	7.60	-	-
10-Apr-25	2375583	TWA002	Washbank Final	Temperature OS*	18.1	-	°C
10-Apr-25	2375586	TWA002	Washbank Final	Turbidity	2.4	±6.1%	NTU
11-Apr-25	2375912	TIB002	Ibisi Final	Al (AE)	484	±7.6%	µg Al/L
11-Apr-25	2375907	TIB002	Ibisi Final	Batch No.*	6248	-	-
11-Apr-25	2375907	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.62	-	mg Cl ₂ /L
11-Apr-25	2375907	TIB002	Ibisi Final	Cl ₂ (T) OS*	0.85	-	mg Cl ₂ /L
11-Apr-25	2375908	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
11-Apr-25	2375908	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
11-Apr-25	2375907	TIB002	Ibisi Final	Coll Time OS*	07:57	-	-
11-Apr-25	2375910	TIB002	Ibisi Final	Colour	<1.00	±6.5%	mg Pt-Co/L
11-Apr-25	2375911	TIB002	Ibisi Final	Conductivity	8.57	±1.5%	mS/m
11-Apr-25	2375908	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
11-Apr-25	2375912	TIB002	Ibisi Final	Fe (AE)	0.22	±5.4%	mg Fe/L
11-Apr-25	2375908	TIB002	Ibisi Final	HPC 37*	18	±21%	cfu/mL
11-Apr-25	2375910	TIB002	Ibisi Final	Odour*	Nil	-	-
11-Apr-25	2375907	TIB002	Ibisi Final	pH OS*	7.40	-	-
11-Apr-25	2375907	TIB002	Ibisi Final	Temperature OS*	19.2	-	°C
11-Apr-25	2375910	TIB002	Ibisi Final	Turbidity	6.1	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

11-Apr-25	2375913	TIB003	Ibisi Police Station Reticulation	Batch No.*	6248	-	-
11-Apr-25	2375913	TIB003	Ibisi Police Station Reticulation	Cl2 (F) OS*	0.62	-	mg Cl2/L
11-Apr-25	2375913	TIB003	Ibisi Police Station Reticulation	Cl2 (T) OS*	0.77	-	mg Cl2/L
11-Apr-25	2375914	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
11-Apr-25	2375913	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	08:10	-	-
11-Apr-25	2375914	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
11-Apr-25	2375914	TIB003	Ibisi Police Station Reticulation	HPC 37*	0	±21%	cfu/mL
11-Apr-25	2375913	TIB003	Ibisi Police Station Reticulation	pH OS*	7.30	-	-
11-Apr-25	2375913	TIB003	Ibisi Police Station Reticulation	Temperature OS*	21.2	-	°C
11-Apr-25	2375916	TIB003	Ibisi Police Station Reticulation	Turbidity	3.3	±6.1%	NTU
11-Apr-25	2375926	TRT002	Rietvlei Final	Al (AE)	339	±7.6%	µg Al/L
11-Apr-25	2375921	TRT002	Rietvlei Final	Batch No.*	6248	-	-
11-Apr-25	2375921	TRT002	Rietvlei Final	Cl2 (F) OS*	1.30	-	mg Cl2/L
11-Apr-25	2375921	TRT002	Rietvlei Final	Cl2 (T) OS*	1.45	-	mg Cl2/L
11-Apr-25	2375922	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
11-Apr-25	2375921	TRT002	Rietvlei Final	Coll Time OS*	07:04	-	-
11-Apr-25	2375925	TRT002	Rietvlei Final	Conductivity	18.1	±1.5%	mS/m
11-Apr-25	2375922	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
11-Apr-25	2375926	TRT002	Rietvlei Final	Fe (AE)	0.06	±5.4%	mg Fe/L
11-Apr-25	2375922	TRT002	Rietvlei Final	HPC 37*	5	±21%	cfu/mL
11-Apr-25	2375926	TRT002	Rietvlei Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
11-Apr-25	2375924	TRT002	Rietvlei Final	Odour*	Nil	-	-
11-Apr-25	2375921	TRT002	Rietvlei Final	pH OS*	7.40	-	-
11-Apr-25	2375921	TRT002	Rietvlei Final	Temperature OS*	18.2	-	°C
11-Apr-25	2375924	TRT002	Rietvlei Final	Turbidity	1.9	±6.1%	NTU
11-Apr-25	2375927	TRT004	Rietvlei Hospital Reticulation	Batch No.*	6248	-	-
11-Apr-25	2375927	TRT004	Rietvlei Hospital Reticulation	Cl2 (F) OS*	1.09	-	mg Cl2/L
11-Apr-25	2375927	TRT004	Rietvlei Hospital Reticulation	Cl2 (T) OS*	1.15	-	mg Cl2/L
11-Apr-25	2375928	TRT004	Rietvlei Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
11-Apr-25	2375927	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	07:15	-	-
11-Apr-25	2375928	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
11-Apr-25	2375928	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
11-Apr-25	2375927	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.30	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Apr-25	2375927	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	19.9	-	°C
11-Apr-25	2375930	TRT004	Rietvlei Hospital Reticulation	Turbidity	3.1	±6.1%	NTU
14-Apr-25	2376656	TFR002	Franklin Final	Al (AE)	825	±7.6%	µg Al/L
14-Apr-25	2376651	TFR002	Franklin Final	Batch No.*	6248	-	-
14-Apr-25	2376651	TFR002	Franklin Final	Cl ₂ (F) OS*	1.20	-	mg Cl ₂ /L
14-Apr-25	2376651	TFR002	Franklin Final	Cl ₂ (T) OS*	1.09	-	mg Cl ₂ /L
14-Apr-25	2376652	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
14-Apr-25	2376652	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
14-Apr-25	2376651	TFR002	Franklin Final	Coll Time OS*	09:28	-	-
14-Apr-25	2376655	TFR002	Franklin Final	Conductivity	16.3	±1.5%	mS/m
14-Apr-25	2376652	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
14-Apr-25	2376652	TFR002	Franklin Final	HPC 37*	2	±21%	cfu/mL
14-Apr-25	2376654	TFR002	Franklin Final	Odour*	Nil	-	-
14-Apr-25	2376651	TFR002	Franklin Final	pH OS*	7.50	-	-
14-Apr-25	2376651	TFR002	Franklin Final	Temperature OS*	24.3	-	°C
14-Apr-25	2376654	TFR002	Franklin Final	Turbidity	3.9	±6.1%	NTU
14-Apr-25	2378673	TIB002	Ibisi Final	Al (AE)	866	±7.6%	µg Al/L
14-Apr-25	2378668	TIB002	Ibisi Final	Batch No.*	6248	-	-
14-Apr-25	2378668	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.82	-	mg Cl ₂ /L
14-Apr-25	2378668	TIB002	Ibisi Final	Cl ₂ (T) OS*	0.90	-	mg Cl ₂ /L
14-Apr-25	2378669	TIB002	Ibisi Final	Coliforms*	1	±15%	MPN/100mL
14-Apr-25	2378669	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
14-Apr-25	2378668	TIB002	Ibisi Final	Coll Time OS*	11:45	-	-
14-Apr-25	2378672	TIB002	Ibisi Final	Conductivity	8.69	±1.5%	mS/m
14-Apr-25	2378669	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
14-Apr-25	2378669	TIB002	Ibisi Final	HPC 37*	17	±21%	cfu/mL
14-Apr-25	2378668	TIB002	Ibisi Final	pH OS*	7.10	-	-
14-Apr-25	2378668	TIB002	Ibisi Final	Temperature OS*	20.9	-	°C
14-Apr-25	2378671	TIB002	Ibisi Final	Turbidity	7.7	±6.1%	NTU
14-Apr-25	2376676	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
14-Apr-25	2376671	TKK002	Kokstad Final	Batch No.*	6248	-	-
14-Apr-25	2376671	TKK002	Kokstad Final	Cl ₂ (F) OS*	0.64	-	mg Cl ₂ /L
14-Apr-25	2376671	TKK002	Kokstad Final	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
14-Apr-25	2376672	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
14-Apr-25	2376672	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
14-Apr-25	2376671	TKK002	Kokstad Final	Coll Time OS*	08:03	-	-
14-Apr-25	2376675	TKK002	Kokstad Final	Conductivity	11.5	±1.5%	mS/m
14-Apr-25	2376672	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
14-Apr-25	2376672	TKK002	Kokstad Final	HPC 37*	1	±21%	cfu/mL
14-Apr-25	2376671	TKK002	Kokstad Final	pH OS*	7.40	-	-
14-Apr-25	2376671	TKK002	Kokstad Final	Temperature OS*	18.3	-	°C
14-Apr-25	2376674	TKK002	Kokstad Final	Turbidity	0.4	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

14-Apr-25	2376719	TNJU002	KwaNjunga Final	Al (AE)	61.0	±7.6%	µg Al/L
14-Apr-25	2376714	TNJU002	KwaNjunga Final	Batch No.*	6248	-	-
14-Apr-25	2376714	TNJU002	KwaNjunga Final	Cl2 (F) OS*	1.35	-	mg Cl2/L
14-Apr-25	2376714	TNJU002	KwaNjunga Final	Cl2 (T) OS*	1.47	-	mg Cl2/L
14-Apr-25	2376715	TNJU002	KwaNjunga Final	Coliforms*	50	±15%	MPN/100mL
14-Apr-25	2376714	TNJU002	KwaNjunga Final	Coll Time OS*	10:13	-	-
14-Apr-25	2376718	TNJU002	KwaNjunga Final	Conductivity	15.4	±1.5%	mS/m
14-Apr-25	2376715	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
14-Apr-25	2376715	TNJU002	KwaNjunga Final	HPC 37*	3	±21%	cfu/mL
14-Apr-25	2376714	TNJU002	KwaNjunga Final	pH OS*	7.40	-	-
14-Apr-25	2376714	TNJU002	KwaNjunga Final	Temperature OS*	20.5	-	°C
14-Apr-25	2376717	TNJU002	KwaNjunga Final	Turbidity	0.9	±6.1%	NTU
15-Apr-25	2377303	TQU002	Mnqumeni Final	Batch No.*	6248	-	-
15-Apr-25	2377303	TQU002	Mnqumeni Final	Cl2 (F) OS*	1.15	-	mg Cl2/L
15-Apr-25	2377303	TQU002	Mnqumeni Final	Cl2 (T) OS*	1.30	-	mg Cl2/L
15-Apr-25	2377304	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
15-Apr-25	2377303	TQU002	Mnqumeni Final	Coll Time OS*	08:13	-	-
15-Apr-25	2377307	TQU002	Mnqumeni Final	Conductivity	10.0	±1.5%	mS/m
15-Apr-25	2377304	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
15-Apr-25	2377304	TQU002	Mnqumeni Final	HPC 37*	16	±21%	cfu/mL
15-Apr-25	2377303	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
15-Apr-25	2377303	TQU002	Mnqumeni Final	Temperature OS*	18.9	-	°C
15-Apr-25	2377306	TQU002	Mnqumeni Final	Turbidity	0.4	±6.1%	NTU
15-Apr-25	2377318	TSQ002	Esiqanduleni Final	Al (AE)	209	±7.6%	µg Al/L
15-Apr-25	2377313	TSQ002	Esiqanduleni Final	Batch No.*	6246	-	-
15-Apr-25	2377313	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	1.45	-	mg Cl2/L
15-Apr-25	2377313	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.62	-	mg Cl2/L
15-Apr-25	2377314	TSQ002	Esiqanduleni Final	Coliforms*	>201	±15%	MPN/100mL
15-Apr-25	2377313	TSQ002	Esiqanduleni Final	Coll Time OS*	07:00	-	-
15-Apr-25	2377317	TSQ002	Esiqanduleni Final	Conductivity	9.51	±1.5%	mS/m
15-Apr-25	2377314	TSQ002	Esiqanduleni Final	E.coli*	21	±14%	MPN/100mL
15-Apr-25	2377314	TSQ002	Esiqanduleni Final	HPC 37*	516	±21%	cfu/mL
15-Apr-25	2377313	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
15-Apr-25	2377313	TSQ002	Esiqanduleni Final	Temperature OS*	18.4	-	°C
15-Apr-25	2377316	TSQ002	Esiqanduleni Final	Turbidity	2.2	±6.1%	NTU
16-Apr-25	2377775	TBU002	Bulwer Final	Batch No.*	6248	-	-
16-Apr-25	2377775	TBU002	Bulwer Final	Cl2 (F) OS*	1.05	-	mg Cl2/L
16-Apr-25	2377775	TBU002	Bulwer Final	Cl2 (T) OS*	1.09	-	mg Cl2/L
16-Apr-25	2377776	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
16-Apr-25	2377775	TBU002	Bulwer Final	Coll Time OS*	10:20	-	-
16-Apr-25	2377779	TBU002	Bulwer Final	Conductivity	4.73	±1.5%	mS/m
16-Apr-25	2377776	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

16-Apr-25	2377776	TBU002	Bulwer Final	HPC 37*	43	±21%	cfu/mL
16-Apr-25	2377775	TBU002	Bulwer Final	pH OS*	7.60	-	-
16-Apr-25	2377775	TBU002	Bulwer Final	Temperature OS*	19.2	-	°C
16-Apr-25	2377778	TBU002	Bulwer Final	Turbidity	8.7	±6.1%	NTU
16-Apr-25	2377790	TCR002	Creighton Final	Al (AE)	281	±7.6%	µg Al/L
16-Apr-25	2377785	TCR002	Creighton Final	Batch No.*	6248	-	-
16-Apr-25	2377785	TCR002	Creighton Final	Cl2 (F) OS*	1.26	-	mg Cl2/L
16-Apr-25	2377785	TCR002	Creighton Final	Cl2 (T) OS*	1.47	-	mg Cl2/L
16-Apr-25	2377786	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
16-Apr-25	2377785	TCR002	Creighton Final	Coll Time OS*	07:00	-	-
16-Apr-25	2377789	TCR002	Creighton Final	Conductivity	8.53	±1.5%	mS/m
16-Apr-25	2377786	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
16-Apr-25	2377786	TCR002	Creighton Final	HPC 37*	4	±21%	cfu/mL
16-Apr-25	2377785	TCR002	Creighton Final	pH OS*	7.30	-	-
16-Apr-25	2377785	TCR002	Creighton Final	Temperature OS*	18.3	-	°C
16-Apr-25	2377788	TCR002	Creighton Final	Turbidity	3.8	±6.1%	NTU
16-Apr-25	2377795	THL002	Hlanganani Final	Batch No.*	6248	-	-
16-Apr-25	2377795	THL002	Hlanganani Final	Cl2 (F) OS*	0.76	-	mg Cl2/L
16-Apr-25	2377795	THL002	Hlanganani Final	Cl2 (T) OS*	0.96	-	mg Cl2/L
16-Apr-25	2377796	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
16-Apr-25	2377795	THL002	Hlanganani Final	Coll Time OS*	11:00	-	-
16-Apr-25	2377799	THL002	Hlanganani Final	Conductivity	7.63	±1.5%	mS/m
16-Apr-25	2377796	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
16-Apr-25	2377796	THL002	Hlanganani Final	HPC 37*	5	±21%	cfu/mL
16-Apr-25	2377795	THL002	Hlanganani Final	pH OS*	7.50	-	-
16-Apr-25	2377795	THL002	Hlanganani Final	Temperature OS*	19.4	-	°C
16-Apr-25	2377798	THL002	Hlanganani Final	Turbidity	0.6	±6.1%	NTU
16-Apr-25	2377818	TMQA002	Mqatsheni Final	Batch No.*	6248	-	-
16-Apr-25	2377818	TMQA002	Mqatsheni Final	Cl2 (F) OS*	1.48	-	mg Cl2/L
16-Apr-25	2377818	TMQA002	Mqatsheni Final	Cl2 (T) OS*	1.61	-	mg Cl2/L
16-Apr-25	2377819	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
16-Apr-25	2377818	TMQA002	Mqatsheni Final	Coll Time OS*	09:14	-	-
16-Apr-25	2377822	TMQA002	Mqatsheni Final	Conductivity	26.5	±1.5%	mS/m
16-Apr-25	2377819	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
16-Apr-25	2377819	TMQA002	Mqatsheni Final	HPC 37*	39	±21%	cfu/mL
16-Apr-25	2377818	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
16-Apr-25	2377818	TMQA002	Mqatsheni Final	Temperature OS*	17.5	-	°C
16-Apr-25	2377821	TMQA002	Mqatsheni Final	Turbidity	1.6	±6.1%	NTU
16-Apr-25	2377833	TRV002	Riverside Final	Al (AE)	70.9	±7.6%	µg Al/L
16-Apr-25	2377828	TRV002	Riverside Final	Batch No.*	6248	-	-
16-Apr-25	2377828	TRV002	Riverside Final	Cl2 (F) OS*	0.48	-	mg Cl2/L
16-Apr-25	2377828	TRV002	Riverside Final	Cl2 (T) OS*	0.99	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

16-Apr-25	2377829	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
16-Apr-25	2377829	TRV002	Riverside Final	Coliphages*	0	±8%	PFU/10ml
16-Apr-25	2377828	TRV002	Riverside Final	Coll Time OS*	08:12	-	-
16-Apr-25	2377832	TRV002	Riverside Final	Conductivity	14.5	±1.5%	mS/m
16-Apr-25	2377829	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
16-Apr-25	2377829	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
16-Apr-25	2377828	TRV002	Riverside Final	pH OS*	7.40	-	-
16-Apr-25	2377828	TRV002	Riverside Final	Temperature OS*	18.1	-	°C
16-Apr-25	2377831	TRV002	Riverside Final	Turbidity	0.7	±6.1%	NTU
16-Apr-25	2377844	TST002	St Appollinaris Final	Al (AE)	496	±7.6%	µg Al/L
16-Apr-25	2377839	TST002	St Appollinaris Final	Batch No.*	6248	-	-
16-Apr-25	2377839	TST002	St Appollinaris Final	Cl2 (F) OS*	1.20	-	mg Cl2/L
16-Apr-25	2377839	TST002	St Appollinaris Final	Cl2 (T) OS*	1.36	-	mg Cl2/L
16-Apr-25	2377840	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
16-Apr-25	2377839	TST002	St Appollinaris Final	Coll Time OS*	09:25	-	-
16-Apr-25	2377843	TST002	St Appollinaris Final	Conductivity	7.96	±1.5%	mS/m
16-Apr-25	2377840	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
16-Apr-25	2377840	TST002	St Appollinaris Final	HPC 37*	5	±21%	cfu/mL
16-Apr-25	2377839	TST002	St Appollinaris Final	pH OS*	7.50	-	-
16-Apr-25	2377839	TST002	St Appollinaris Final	Temperature OS*	19.6	-	°C
16-Apr-25	2377842	TST002	St Appollinaris Final	Turbidity	9.4	±6.1%	NTU
16-Apr-25	2377855	TUN002	Underberg Final	Al (AE)	118	±7.6%	µg Al/L
16-Apr-25	2377850	TUN002	Underberg Final	Batch No.*	6248	-	-
16-Apr-25	2377850	TUN002	Underberg Final	Cl2 (F) OS*	0.58	-	mg Cl2/L
16-Apr-25	2377850	TUN002	Underberg Final	Cl2 (T) OS*	0.69	-	mg Cl2/L
16-Apr-25	2377851	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
16-Apr-25	2377850	TUN002	Underberg Final	Coll Time OS*	10:04	-	-
16-Apr-25	2377854	TUN002	Underberg Final	Conductivity	6.85	±1.5%	mS/m
16-Apr-25	2377851	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
16-Apr-25	2377851	TUN002	Underberg Final	HPC 37*	0	±21%	cfu/mL
16-Apr-25	2377850	TUN002	Underberg Final	pH OS*	7.30	-	-
16-Apr-25	2377850	TUN002	Underberg Final	Temperature OS*	17.2	-	°C
16-Apr-25	2377853	TUN002	Underberg Final	Turbidity	0.7	±6.1%	NTU
17-Apr-25	2378504	TMZ002	Umzimkhulu Final	Al (AE)	394	±7.6%	µg Al/L
17-Apr-25	2378499	TMZ002	Umzimkhulu Final	Batch No.*	6248	-	-
17-Apr-25	2378499	TMZ002	Umzimkhulu Final	Cl2 (F) OS*	1.35	-	mg Cl2/L
17-Apr-25	2378499	TMZ002	Umzimkhulu Final	Cl2 (T) OS*	1.40	-	mg Cl2/L
17-Apr-25	2378500	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
17-Apr-25	2378500	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
17-Apr-25	2378499	TMZ002	Umzimkhulu Final	Coll Time OS*	07:20	-	-
17-Apr-25	2378503	TMZ002	Umzimkhulu Final	Conductivity	9.83	±1.5%	mS/m
17-Apr-25	2378500	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

17-Apr-25	2378500	TMZ002	Umzimkhulu Final	HPC 37*	23	±21%	cfu/mL
17-Apr-25	2378499	TMZ002	Umzimkhulu Final	pH OS*	7.60	-	-
17-Apr-25	2378499	TMZ002	Umzimkhulu Final	Temperature OS*	19.3	-	°C
17-Apr-25	2378502	TMZ002	Umzimkhulu Final	Turbidity	16.8	±6.1%	NTU
17-Apr-25	2378515	TNO002	Nokweja Final	Al (AE)	666	±7.6%	µg Al/L
17-Apr-25	2378510	TNO002	Nokweja Final	Batch No.*	6248	-	-
17-Apr-25	2378510	TNO002	Nokweja Final	Cl2 (F) OS*	0.74	-	mg Cl2/L
17-Apr-25	2378510	TNO002	Nokweja Final	Cl2 (T) OS*	0.86	-	mg Cl2/L
17-Apr-25	2378511	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
17-Apr-25	2378511	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
17-Apr-25	2378510	TNO002	Nokweja Final	Coll Time OS*	07:12	-	-
17-Apr-25	2378514	TNO002	Nokweja Final	Conductivity	8.63	±1.5%	mS/m
17-Apr-25	2378511	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
17-Apr-25	2378511	TNO002	Nokweja Final	HPC 37*	25	±21%	cfu/mL
17-Apr-25	2378510	TNO002	Nokweja Final	pH OS*	7.40	-	-
17-Apr-25	2378510	TNO002	Nokweja Final	Temperature OS*	17.4	-	°C
17-Apr-25	2378513	TNO002	Nokweja Final	Turbidity	3.2	±6.1%	NTU
17-Apr-25	2378526	TWA002	Washbank Final	Al (AE)	35.0	±7.6%	µg Al/L
17-Apr-25	2378521	TWA002	Washbank Final	Batch No.*	6248	-	-
17-Apr-25	2378521	TWA002	Washbank Final	Cl2 (F) OS*	0.47	-	mg Cl2/L
17-Apr-25	2378521	TWA002	Washbank Final	Cl2 (T) OS*	0.56	-	mg Cl2/L
17-Apr-25	2378522	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
17-Apr-25	2378521	TWA002	Washbank Final	Coll Time OS*	06:00	-	-
17-Apr-25	2378525	TWA002	Washbank Final	Conductivity	9.97	±1.5%	mS/m
17-Apr-25	2378522	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
17-Apr-25	2378522	TWA002	Washbank Final	HPC 37*	281	±21%	cfu/mL
17-Apr-25	2378521	TWA002	Washbank Final	pH OS*	7.30	-	-
17-Apr-25	2378521	TWA002	Washbank Final	Temperature OS*	18.1	-	°C
17-Apr-25	2378524	TWA002	Washbank Final	Turbidity	1.3	±6.1%	NTU
22-Apr-25	2381816	TSQ002	Esiqanduleni Final	Al (AE)	149	±7.6%	µg Al/L
22-Apr-25	2381811	TSQ002	Esiqanduleni Final	Batch No.*	6248	-	-
22-Apr-25	2381811	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	1.09	-	mg Cl2/L
22-Apr-25	2381811	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.21	-	mg Cl2/L
22-Apr-25	2381812	TSQ002	Esiqanduleni Final	Coliforms*	48	±15%	MPN/100mL
22-Apr-25	2381811	TSQ002	Esiqanduleni Final	Coll Time OS*	06:20	-	-
22-Apr-25	2381814	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Apr-25	2381815	TSQ002	Esiqanduleni Final	Conductivity	10.5	±1.5%	mS/m
22-Apr-25	2381812	TSQ002	Esiqanduleni Final	E.coli*	8	±14%	MPN/100mL
22-Apr-25	2381812	TSQ002	Esiqanduleni Final	HPC 37*	78	±21%	cfu/mL
22-Apr-25	2381814	TSQ002	Esiqanduleni Final	Odour*	Nil	-	-
22-Apr-25	2381811	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
22-Apr-25	2381811	TSQ002	Esiqanduleni Final	Temperature OS*	18.3	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

22-Apr-25	2381814	TSQ002	Esiqanduleni Final	Turbidity	2.6	±6.1%	NTU
22-Apr-25	2381817	TSQ003	Esiqanduleni Reticulation	Batch No.*	6248	-	-
22-Apr-25	2381817	TSQ003	Esiqanduleni Reticulation	Cl ₂ (F) OS*	0.84	-	mg Cl ₂ /L
22-Apr-25	2381817	TSQ003	Esiqanduleni Reticulation	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
22-Apr-25	2381818	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL
22-Apr-25	2381817	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	06:40	-	-
22-Apr-25	2381818	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
22-Apr-25	2381818	TSQ003	Esiqanduleni Reticulation	HPC 37*	16	±21%	cfu/mL
22-Apr-25	2381817	TSQ003	Esiqanduleni Reticulation	pH OS*	7.40	-	-
22-Apr-25	2381817	TSQ003	Esiqanduleni Reticulation	Temperature OS*	18.4	-	°C
22-Apr-25	2381820	TSQ003	Esiqanduleni Reticulation	Turbidity	4.0	±6.1%	NTU
23-Apr-25	2382380	TBU002	Bulwer Final	Batch No.*	6248	-	-
23-Apr-25	2382380	TBU002	Bulwer Final	Cl ₂ (F) OS*	0.55	-	mg Cl ₂ /L
23-Apr-25	2382380	TBU002	Bulwer Final	Cl ₂ (T) OS*	0.98	-	mg Cl ₂ /L
23-Apr-25	2382381	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382380	TBU002	Bulwer Final	Coll Time OS*	11:26	-	-
23-Apr-25	2382383	TBU002	Bulwer Final	Colour	1.00	±6.5%	mg Pt-Co/L
23-Apr-25	2382384	TBU002	Bulwer Final	Conductivity	4.60	±1.5%	mS/m
23-Apr-25	2382381	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382381	TBU002	Bulwer Final	HPC 37*	8	±21%	cfu/mL
23-Apr-25	2382383	TBU002	Bulwer Final	Odour*	Nil	-	-
23-Apr-25	2382380	TBU002	Bulwer Final	pH OS*	7.40	-	-
23-Apr-25	2382380	TBU002	Bulwer Final	Temperature OS*	18.1	-	°C
23-Apr-25	2382383	TBU002	Bulwer Final	Turbidity	7.8	±6.1%	NTU
23-Apr-25	2382385	TBU005	Bulwer Mountain Park Hotel Retic	Batch No.*	6248	-	-
23-Apr-25	2382385	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (F) OS*	<0.05	-	mg Cl ₂ /L
23-Apr-25	2382385	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (T) OS*	<0.05	-	mg Cl ₂ /L
23-Apr-25	2382386	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382385	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	11:40	-	-
23-Apr-25	2382386	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382386	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	0	±21%	cfu/mL
23-Apr-25	2382385	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.60	-	-
23-Apr-25	2382385	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	19.5	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

23-Apr-25	2382388	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	2.4	±6.1%	NTU
23-Apr-25	2382399	TCR002	Creighton Final	Al (AE)	1251	±7.6%	µg Al/L
23-Apr-25	2382394	TCR002	Creighton Final	Batch No.*	6248	-	-
23-Apr-25	2382394	TCR002	Creighton Final	Cl ₂ (F) OS*	0.68	-	mg Cl ₂ /L
23-Apr-25	2382394	TCR002	Creighton Final	Cl ₂ (T) OS*	0.89	-	mg Cl ₂ /L
23-Apr-25	2382395	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382394	TCR002	Creighton Final	Coll Time OS*	09:10	-	-
23-Apr-25	2382398	TCR002	Creighton Final	Conductivity	8.19	±1.5%	mS/m
23-Apr-25	2382395	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382395	TCR002	Creighton Final	HPC 37*	2	±21%	cfu/mL
23-Apr-25	2382394	TCR002	Creighton Final	pH OS*	7.40	-	-
23-Apr-25	2382394	TCR002	Creighton Final	Temperature OS*	18.8	-	°C
23-Apr-25	2382397	TCR002	Creighton Final	Turbidity	5.2	±6.1%	NTU
23-Apr-25	2382428	THL002	Hlanganani Final	Batch No.*	6248	-	-
23-Apr-25	2382428	THL002	Hlanganani Final	Cl ₂ (F) OS*	0.60	-	mg Cl ₂ /L
23-Apr-25	2382428	THL002	Hlanganani Final	Cl ₂ (T) OS*	0.68	-	mg Cl ₂ /L
23-Apr-25	2382429	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382428	THL002	Hlanganani Final	Coll Time OS*	12:00	-	-
23-Apr-25	2382431	THL002	Hlanganani Final	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Apr-25	2382432	THL002	Hlanganani Final	Conductivity	7.09	±1.5%	mS/m
23-Apr-25	2382429	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382429	THL002	Hlanganani Final	HPC 37*	3	±21%	cfu/mL
23-Apr-25	2382431	THL002	Hlanganani Final	Odour*	Nil	-	-
23-Apr-25	2382428	THL002	Hlanganani Final	pH OS*	7.50	-	-
23-Apr-25	2382431	THL002	Hlanganani Final	Taste*	Nil	-	-
23-Apr-25	2382428	THL002	Hlanganani Final	Temperature OS*	18.1	-	°C
23-Apr-25	2382431	THL002	Hlanganani Final	Turbidity	0.5	±6.1%	NTU
23-Apr-25	2382433	THL003	Hlanganani Clinic Reticulation	Batch No.*	6248	-	-
23-Apr-25	2382433	THL003	Hlanganani Clinic Reticulation	Cl ₂ (F) OS*	0.34	-	mg Cl ₂ /L
23-Apr-25	2382433	THL003	Hlanganani Clinic Reticulation	Cl ₂ (T) OS*	0.46	-	mg Cl ₂ /L
23-Apr-25	2382434	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382433	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	12:33	-	-
23-Apr-25	2382434	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382434	THL003	Hlanganani Clinic Reticulation	HPC 37*	0	±21%	cfu/mL
23-Apr-25	2382433	THL003	Hlanganani Clinic Reticulation	pH OS*	7.40	-	-
23-Apr-25	2382433	THL003	Hlanganani Clinic Reticulation	Temperature OS*	15.0	-	°C
23-Apr-25	2382436	THL003	Hlanganani Clinic Reticulation	Turbidity	0.6	±6.1%	NTU
23-Apr-25	2382450	TMAN002	Mangwaneni Final	Batch No.*	6248	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolu | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

23-Apr-25	2382450	TMAN002	Mangwaneni Final	Cl2 (F) OS*	0.76	-	mg Cl2/L
23-Apr-25	2382450	TMAN002	Mangwaneni Final	Cl2 (T) OS*	0.98	-	mg Cl2/L
23-Apr-25	2382451	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382450	TMAN002	Mangwaneni Final	Coll Time OS*	13:11	-	-
23-Apr-25	2382453	TMAN002	Mangwaneni Final	Colour	1.00	±6.5%	mg Pt-Co/L
23-Apr-25	2382454	TMAN002	Mangwaneni Final	Conductivity	9.61	±1.5%	mS/m
23-Apr-25	2382451	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382451	TMAN002	Mangwaneni Final	HPC 37*	5	±21%	cfu/mL
23-Apr-25	2382453	TMAN002	Mangwaneni Final	Odour*	Nil	-	-
23-Apr-25	2382450	TMAN002	Mangwaneni Final	pH OS*	7.20	-	-
23-Apr-25	2382450	TMAN002	Mangwaneni Final	Temperature OS*	18.3	-	°C
23-Apr-25	2382453	TMAN002	Mangwaneni Final	Turbidity	7.1	±6.1%	NTU
23-Apr-25	2382459	TMQA002	Mqatsheni Final	Batch No.*	6248	-	-
23-Apr-25	2382459	TMQA002	Mqatsheni Final	Cl2 (F) OS*	0.98	-	mg Cl2/L
23-Apr-25	2382459	TMQA002	Mqatsheni Final	Cl2 (T) OS*	1.01	-	mg Cl2/L
23-Apr-25	2382460	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382459	TMQA002	Mqatsheni Final	Coll Time OS*	11:18	-	-
23-Apr-25	2382463	TMQA002	Mqatsheni Final	Colour	1.20	±6.5%	mg Pt-Co/L
23-Apr-25	2382464	TMQA002	Mqatsheni Final	Conductivity	26.6	±1.5%	mS/m
23-Apr-25	2382460	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382460	TMQA002	Mqatsheni Final	HPC 37*	2	±21%	cfu/mL
23-Apr-25	2382463	TMQA002	Mqatsheni Final	Odour*	Nil	-	-
23-Apr-25	2382459	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
23-Apr-25	2382459	TMQA002	Mqatsheni Final	Temperature OS*	17.2	-	°C
23-Apr-25	2382463	TMQA002	Mqatsheni Final	Turbidity	0.9	±6.1%	NTU
23-Apr-25	2382465	TMQA003	Mqatsheni Reticulation	Batch No.*	6248	-	-
23-Apr-25	2382465	TMQA003	Mqatsheni Reticulation	Cl2 (F) OS*	0.46	-	mg Cl2/L
23-Apr-25	2382465	TMQA003	Mqatsheni Reticulation	Cl2 (T) OS*	0.66	-	mg Cl2/L
23-Apr-25	2382466	TMQA003	Mqatsheni Reticulation	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382465	TMQA003	Mqatsheni Reticulation	Coll Time OS*	10:55	-	-
23-Apr-25	2382466	TMQA003	Mqatsheni Reticulation	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382466	TMQA003	Mqatsheni Reticulation	HPC 37*	0	±21%	cfu/mL
23-Apr-25	2382465	TMQA003	Mqatsheni Reticulation	pH OS*	8.70	-	-
23-Apr-25	2382465	TMQA003	Mqatsheni Reticulation	Temperature OS*	17.1	-	°C
23-Apr-25	2382468	TMQA003	Mqatsheni Reticulation	Turbidity	0.6	±6.1%	NTU
23-Apr-25	2382479	TRV002	Riverside Final	Al (AE)	101	±7.6%	µg Al/L
23-Apr-25	2382474	TRV002	Riverside Final	Batch No.*	6248	-	-
23-Apr-25	2382474	TRV002	Riverside Final	Cl2 (F) OS*	0.16	-	mg Cl2/L
23-Apr-25	2382474	TRV002	Riverside Final	Cl2 (T) OS*	0.30	-	mg Cl2/L
23-Apr-25	2382475	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382475	TRV002	Riverside Final	Coliphages*	0	±8%	PFU/10ml
23-Apr-25	2382474	TRV002	Riverside Final	Coll Time OS*	09:45	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

23-Apr-25	2382477	TRV002	Riverside Final	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Apr-25	2382478	TRV002	Riverside Final	Conductivity	12.9	±1.5%	mS/m
23-Apr-25	2382475	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382475	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
23-Apr-25	2382477	TRV002	Riverside Final	Odour*	Nil	-	-
23-Apr-25	2382474	TRV002	Riverside Final	pH OS*	7.10	-	-
23-Apr-25	2382474	TRV002	Riverside Final	Temperature OS*	16.2	-	°C
23-Apr-25	2382477	TRV002	Riverside Final	Turbidity	0.6	±6.1%	NTU
23-Apr-25	2382480	TRV003	Riverside Reticulation	Batch No.*	6248	-	-
23-Apr-25	2382480	TRV003	Riverside Reticulation	Cl ₂ (F) OS*	0.22	-	mg Cl ₂ /L
23-Apr-25	2382480	TRV003	Riverside Reticulation	Cl ₂ (T) OS*	0.30	-	mg Cl ₂ /L
23-Apr-25	2382481	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382480	TRV003	Riverside Reticulation	Coll Time OS*	09:38	-	-
23-Apr-25	2382481	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382481	TRV003	Riverside Reticulation	HPC 37*	0	±21%	cfu/mL
23-Apr-25	2382480	TRV003	Riverside Reticulation	pH OS*	7.20	-	-
23-Apr-25	2382480	TRV003	Riverside Reticulation	Temperature OS*	14.2	-	°C
23-Apr-25	2382483	TRV003	Riverside Reticulation	Turbidity	3.0	±6.1%	NTU
23-Apr-25	2382494	TST002	St Appollinaris Final	Al (AE)	525	±7.6%	µg Al/L
23-Apr-25	2382489	TST002	St Appollinaris Final	Batch No.*	6248	-	-
23-Apr-25	2382489	TST002	St Appollinaris Final	Cl ₂ (F) OS*	2.50	-	mg Cl ₂ /L
23-Apr-25	2382489	TST002	St Appollinaris Final	Cl ₂ (T) OS*	3.50	-	mg Cl ₂ /L
23-Apr-25	2382490	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382489	TST002	St Appollinaris Final	Coll Time OS*	10:45	-	-
23-Apr-25	2382492	TST002	St Appollinaris Final	Colour	13.2	±6.5%	mg Pt-Co/L
23-Apr-25	2382493	TST002	St Appollinaris Final	Conductivity	9.76	±1.5%	mS/m
23-Apr-25	2382490	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382490	TST002	St Appollinaris Final	HPC 37*	0	±21%	cfu/mL
23-Apr-25	2382492	TST002	St Appollinaris Final	Odour*	Nil	-	-
23-Apr-25	2382489	TST002	St Appollinaris Final	pH OS*	7.40	-	-
23-Apr-25	2382489	TST002	St Appollinaris Final	Temperature OS*	19.3	-	°C
23-Apr-25	2382492	TST002	St Appollinaris Final	Turbidity	10.1	±6.1%	NTU
23-Apr-25	2382505	TUN002	Underberg Final	Al (AE)	77.8	±7.6%	µg Al/L
23-Apr-25	2382500	TUN002	Underberg Final	Batch No.*	6248	-	-
23-Apr-25	2382500	TUN002	Underberg Final	Cl ₂ (F) OS*	0.46	-	mg Cl ₂ /L
23-Apr-25	2382500	TUN002	Underberg Final	Cl ₂ (T) OS*	0.58	-	mg Cl ₂ /L
23-Apr-25	2382501	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
23-Apr-25	2382500	TUN002	Underberg Final	Coll Time OS*	09:40	-	-
23-Apr-25	2382503	TUN002	Underberg Final	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Apr-25	2382504	TUN002	Underberg Final	Conductivity	6.17	±1.5%	mS/m
23-Apr-25	2382501	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
23-Apr-25	2382501	TUN002	Underberg Final	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

23-Apr-25	2382503	TUN002	Underberg Final	Odour*	Nil	-	-
23-Apr-25	2382500	TUN002	Underberg Final	pH OS*	7.70	-	-
23-Apr-25	2382500	TUN002	Underberg Final	Temperature OS*	15.8	-	°C
23-Apr-25	2382503	TUN002	Underberg Final	Turbidity	1.0	±6.1%	NTU
24-Apr-25	2383103	TMZ002	Umzimkhulu Final	Al (AE)	588	±7.6%	µg Al/L
24-Apr-25	2383098	TMZ002	Umzimkhulu Final	Batch No.*	6248	-	-
24-Apr-25	2383098	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	0.21	-	mg Cl ₂ /L
24-Apr-25	2383098	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	0.39	-	mg Cl ₂ /L
24-Apr-25	2383099	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
24-Apr-25	2383099	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
24-Apr-25	2383098	TMZ002	Umzimkhulu Final	Coll Time OS*	08:07	-	-
24-Apr-25	2383101	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Apr-25	2383102	TMZ002	Umzimkhulu Final	Conductivity	9.48	±1.5%	mS/m
24-Apr-25	2383099	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
24-Apr-25	2383099	TMZ002	Umzimkhulu Final	HPC 37*	71	±21%	cfu/mL
24-Apr-25	2383101	TMZ002	Umzimkhulu Final	Odour*	Nil	-	-
24-Apr-25	2383098	TMZ002	Umzimkhulu Final	pH OS*	6.40	-	-
24-Apr-25	2383098	TMZ002	Umzimkhulu Final	Temperature OS*	17.5	-	°C
24-Apr-25	2383101	TMZ002	Umzimkhulu Final	Turbidity	14.2	±6.1%	NTU
24-Apr-25	2383104	TMZ004	Umzikhulu Informal Settlement Retic	Batch No.*	6248	-	-
24-Apr-25	2383104	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (F) OS*	0.06	-	mg Cl ₂ /L
24-Apr-25	2383104	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (T) OS*	0.11	-	mg Cl ₂ /L
24-Apr-25	2383105	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	0	±15%	MPN/100mL
24-Apr-25	2383104	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	08:20	-	-
24-Apr-25	2383107	TMZ004	Umzikhulu Informal Settlement Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Apr-25	2383108	TMZ004	Umzikhulu Informal Settlement Retic	Conductivity	9.45	±1.5%	mS/m
24-Apr-25	2383105	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
24-Apr-25	2383105	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	61	±21%	cfu/mL
24-Apr-25	2383107	TMZ004	Umzikhulu Informal Settlement Retic	Odour*	Nil	-	-
24-Apr-25	2383104	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.60	-	-
24-Apr-25	2383104	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	19.6	-	°C
24-Apr-25	2383107	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	10.7	±6.1%	NTU
24-Apr-25	2383109	TMZ005	Umzimkhulu Local Municipality Offices	Batch No.*	6248	-	-
24-Apr-25	2383109	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (F) OS*	0.16	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

24-Apr-25	2383109	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (T) OS*	0.20	-	mg Cl ₂ /L
24-Apr-25	2383110	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	3	±15%	MPN/100mL
24-Apr-25	2383109	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	08;20	-	-
24-Apr-25	2383112	TMZ005	Umzimkhulu Local Municipality Offices	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Apr-25	2383113	TMZ005	Umzimkhulu Local Municipality Offices	Conductivity	9.52	±1.5%	mS/m
24-Apr-25	2383110	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
24-Apr-25	2383110	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	37	±21%	cfu/mL
24-Apr-25	2383109	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.40	-	-
24-Apr-25	2383109	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	19.2	-	°C
24-Apr-25	2383112	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	10.9	±6.1%	NTU
24-Apr-25	2383114	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Batch No.*	6248	-	-
24-Apr-25	2383114	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (F) OS*	0.09	-	mg Cl ₂ /L
24-Apr-25	2383114	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (T) OS*	0.24	-	mg Cl ₂ /L
24-Apr-25	2383115	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coliforms*	27	±15%	MPN/100mL
24-Apr-25	2383114	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coll Time OS*	08:30	-	-
24-Apr-25	2383117	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Apr-25	2383118	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Conductivity	8.26	±1.5%	mS/m
24-Apr-25	2383115	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	E.coli*	1	±14%	MPN/100mL
24-Apr-25	2383115	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	HPC 37*	15	±21%	cfu/mL
24-Apr-25	2383114	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	6.10	-	-
24-Apr-25	2383114	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	18.2	-	°C
24-Apr-25	2383117	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	4.9	±6.1%	NTU
24-Apr-25	2383119	TMZ007	Umzimkhulu Local FET College	Batch No.*	6248	-	-
24-Apr-25	2383119	TMZ007	Umzimkhulu Local FET College	Cl ₂ (F) OS*	0.16	-	mg Cl ₂ /L
24-Apr-25	2383119	TMZ007	Umzimkhulu Local FET College	Cl ₂ (T) OS*	0.20	-	mg Cl ₂ /L
24-Apr-25	2383120	TMZ007	Umzimkhulu Local FET College	Coliforms*	1	±15%	MPN/100mL
24-Apr-25	2383119	TMZ007	Umzimkhulu Local FET College	Coll Time OS*	08:20	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

24-Apr-25	2383122	TMZ007	Umzimkhulu Local FET College	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Apr-25	2383123	TMZ007	Umzimkhulu Local FET College	Conductivity	8.43	±1.5%	mS/m
24-Apr-25	2383120	TMZ007	Umzimkhulu Local FET College	E.coli*	0	±14%	MPN/100mL
24-Apr-25	2383120	TMZ007	Umzimkhulu Local FET College	HPC 37*	52	±21%	cfu/mL
24-Apr-25	2383119	TMZ007	Umzimkhulu Local FET College	pH OS*	7.40	-	-
24-Apr-25	2383119	TMZ007	Umzimkhulu Local FET College	Temperature OS*	19.2	-	°C
24-Apr-25	2383122	TMZ007	Umzimkhulu Local FET College	Turbidity	74.2	±6.1%	NTU
24-Apr-25	2383134	TNO002	Nokweja Final	Al (AE)	395	±7.6%	µg Al/L
24-Apr-25	2383129	TNO002	Nokweja Final	Batch No.*	6248	-	-
24-Apr-25	2383129	TNO002	Nokweja Final	Cl ₂ (F) OS*	0.58	-	mg Cl ₂ /L
24-Apr-25	2383129	TNO002	Nokweja Final	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
24-Apr-25	2383130	TNO002	Nokweja Final	Coliforms*	5	±15%	MPN/100mL
24-Apr-25	2383130	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
24-Apr-25	2383129	TNO002	Nokweja Final	Coll Time OS*	07:10	-	-
24-Apr-25	2383132	TNO002	Nokweja Final	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Apr-25	2383133	TNO002	Nokweja Final	Conductivity	9.79	±1.5%	mS/m
24-Apr-25	2383130	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
24-Apr-25	2383130	TNO002	Nokweja Final	HPC 37*	43	±21%	cfu/mL
24-Apr-25	2383132	TNO002	Nokweja Final	Odour*	Nil	-	-
24-Apr-25	2383129	TNO002	Nokweja Final	pH OS*	7.20	-	-
24-Apr-25	2383129	TNO002	Nokweja Final	Temperature OS*	17.0	-	°C
24-Apr-25	2383132	TNO002	Nokweja Final	Turbidity	7.7	±6.1%	NTU
24-Apr-25	2383155	TWA002	Washbank Final	Al (AE)	197	±7.6%	µg Al/L
24-Apr-25	2383150	TWA002	Washbank Final	Batch No.*	6248	-	-
24-Apr-25	2383150	TWA002	Washbank Final	Cl ₂ (F) OS*	1.74	-	mg Cl ₂ /L
24-Apr-25	2383150	TWA002	Washbank Final	Cl ₂ (T) OS*	1.99	-	mg Cl ₂ /L
24-Apr-25	2383151	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
24-Apr-25	2383150	TWA002	Washbank Final	Coll Time OS*	07:45	-	-
24-Apr-25	2383153	TWA002	Washbank Final	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Apr-25	2383154	TWA002	Washbank Final	Conductivity	8.31	±1.5%	mS/m
24-Apr-25	2383151	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
24-Apr-25	2383151	TWA002	Washbank Final	HPC 37*	0	±21%	cfu/mL
24-Apr-25	2383153	TWA002	Washbank Final	Odour*	Nil	-	-
24-Apr-25	2383150	TWA002	Washbank Final	Temperature OS*	17.1	-	°C
24-Apr-25	2383153	TWA002	Washbank Final	Turbidity	1.2	±6.1%	NTU
25-Apr-25	2382419	TFR002	Franklin Final	Al (AE)	348	±7.6%	µg Al/L
25-Apr-25	2382414	TFR002	Franklin Final	Batch No.*	6248	-	-
25-Apr-25	2382414	TFR002	Franklin Final	Cl ₂ (F) OS*	1.35	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

25-Apr-25	2382414	TFR002	Franklin Final	Cl2 (T) OS*	1.42	-	mg Cl2/L
25-Apr-25	2382415	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2382415	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
25-Apr-25	2382414	TFR002	Franklin Final	Coll Time OS*	08:16	-	-
25-Apr-25	2382417	TFR002	Franklin Final	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Apr-25	2382418	TFR002	Franklin Final	Conductivity	16.4	±1.5%	mS/m
25-Apr-25	2382415	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2382419	TFR002	Franklin Final	Fe (AE)	1.68	±5.4%	mg Fe/L
25-Apr-25	2382415	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2382419	TFR002	Franklin Final	Mn (AE)	0.03	±6.2%	mg Mn/L
25-Apr-25	2382414	TFR002	Franklin Final	pH OS*	7.40	-	-
25-Apr-25	2382414	TFR002	Franklin Final	Temperature OS*	14.8	-	°C
25-Apr-25	2382417	TFR002	Franklin Final	Turbidity	2.1	±6.1%	NTU
25-Apr-25	2382420	TFR003	Franklin Police Station Retic	Batch No.*	6248	-	-
25-Apr-25	2382420	TFR003	Franklin Police Station Retic	Cl2 (F) OS*	1.64	-	mg Cl2/L
25-Apr-25	2382420	TFR003	Franklin Police Station Retic	Cl2 (T) OS*	1.80	-	mg Cl2/L
25-Apr-25	2382421	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2382420	TFR003	Franklin Police Station Retic	Coll Time OS*	07:55	-	-
25-Apr-25	2382421	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2382421	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2382420	TFR003	Franklin Police Station Retic	pH OS*	7.20	-	-
25-Apr-25	2382420	TFR003	Franklin Police Station Retic	Temperature OS*	15.8	-	°C
25-Apr-25	2382423	TFR003	Franklin Police Station Retic	Turbidity	1.5	±6.1%	NTU
25-Apr-25	2383417	TIB002	Ibisi Final	Al (AE)	1064	±7.6%	µg Al/L
25-Apr-25	2383412	TIB002	Ibisi Final	Batch No.*	6248	-	-
25-Apr-25	2383412	TIB002	Ibisi Final	Cl2 (F) OS*	1.18	-	mg Cl2/L
25-Apr-25	2383412	TIB002	Ibisi Final	Cl2 (T) OS*	1.32	-	mg Cl2/L
25-Apr-25	2383413	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2383413	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
25-Apr-25	2383412	TIB002	Ibisi Final	Coll Time OS*	11:25	-	-
25-Apr-25	2383415	TIB002	Ibisi Final	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Apr-25	2383416	TIB002	Ibisi Final	Conductivity	8.34	±1.5%	mS/m
25-Apr-25	2383413	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2383413	TIB002	Ibisi Final	HPC 37*	63	±21%	cfu/mL
25-Apr-25	2383415	TIB002	Ibisi Final	Odour*	Nil	-	-
25-Apr-25	2383412	TIB002	Ibisi Final	pH OS*	7.30	-	-
25-Apr-25	2383412	TIB002	Ibisi Final	Temperature OS*	18.4	-	°C
25-Apr-25	2383415	TIB002	Ibisi Final	Turbidity	27.1	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

25-Apr-25	2383418	TIB003	Ibisi Police Station Reticulation	Batch No.*	6248	-	-
25-Apr-25	2383418	TIB003	Ibisi Police Station Reticulation	Cl2 (F) OS*	0.68	-	mg Cl2/L
25-Apr-25	2383418	TIB003	Ibisi Police Station Reticulation	Cl2 (T) OS*	0.88	-	mg Cl2/L
25-Apr-25	2383419	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2383418	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	11:30	-	-
25-Apr-25	2383421	TIB003	Ibisi Police Station Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Apr-25	2383422	TIB003	Ibisi Police Station Reticulation	Conductivity	8.12	±1.5%	mS/m
25-Apr-25	2383419	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2383419	TIB003	Ibisi Police Station Reticulation	HPC 37*	7	±21%	cfu/mL
25-Apr-25	2383418	TIB003	Ibisi Police Station Reticulation	pH OS*	7.20	-	-
25-Apr-25	2383418	TIB003	Ibisi Police Station Reticulation	Temperature OS*	20.1	-	°C
25-Apr-25	2383421	TIB003	Ibisi Police Station Reticulation	Turbidity	9.0	±6.1%	NTU
25-Apr-25	2384656	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
25-Apr-25	2384651	TKK002	Kokstad Final	Batch No.*	6248	-	-
25-Apr-25	2384651	TKK002	Kokstad Final	Cl2 (F) OS*	0.80	-	mg Cl2/L
25-Apr-25	2384651	TKK002	Kokstad Final	Cl2 (T) OS*	0.92	-	mg Cl2/L
25-Apr-25	2384652	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2384652	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
25-Apr-25	2384651	TKK002	Kokstad Final	Coll Time OS*	07:45	-	-
25-Apr-25	2384654	TKK002	Kokstad Final	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Apr-25	2384655	TKK002	Kokstad Final	Conductivity	8.62	±1.5%	mS/m
25-Apr-25	2384652	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2384652	TKK002	Kokstad Final	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2384654	TKK002	Kokstad Final	Odour*	Nil	-	-
25-Apr-25	2384651	TKK002	Kokstad Final	pH OS*	7.40	-	-
25-Apr-25	2384654	TKK002	Kokstad Final	Taste*	Nil	-	-
25-Apr-25	2384651	TKK002	Kokstad Final	Temperature OS*	19.8	-	°C
25-Apr-25	2384654	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
25-Apr-25	2384666	TKK006	Kokstad Bongweni Correctional Serv Retic	Batch No.*	6248	-	-
25-Apr-25	2384666	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (F) OS*	0.36	-	mg Cl2/L
25-Apr-25	2384666	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (T) OS*	0.46	-	mg Cl2/L
25-Apr-25	2384667	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2384666	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	07:20	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

25-Apr-25	2384667	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2384667	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2384666	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.50	-	-
25-Apr-25	2384666	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	20.0	-	°C
25-Apr-25	2384669	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	<0.2	±6.1%	NTU
25-Apr-25	2384670	TKK007	Kokstad Shayamoya Reticulation	Batch No.*	6248	-	-
25-Apr-25	2384670	TKK007	Kokstad Shayamoya Reticulation	Cl2 (F) OS*	0.56	-	mg Cl2/L
25-Apr-25	2384670	TKK007	Kokstad Shayamoya Reticulation	Cl2 (T) OS*	0.70	-	mg Cl2/L
25-Apr-25	2384671	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2384670	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	08:00	-	-
25-Apr-25	2384671	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2384671	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2384670	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.40	-	-
25-Apr-25	2384670	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	19.2	-	°C
25-Apr-25	2384673	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.2	±6.1%	NTU
25-Apr-25	2384674	TKK009	Kokstad Farm Fresh Produce Market	Batch No.*	6248	-	-
25-Apr-25	2384674	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (F) OS*	1.09	-	mg Cl2/L
25-Apr-25	2384674	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (T) OS*	1.22	-	mg Cl2/L
25-Apr-25	2384675	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2384674	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	08:28	-	-
25-Apr-25	2384675	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2384675	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2384674	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.40	-	-
25-Apr-25	2384674	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	16.5	-	°C
25-Apr-25	2384677	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.2	±6.1%	NTU
25-Apr-25	2384678	TKK012	Kokstad FET College Reticulation	Batch No.*	6248	-	-
25-Apr-25	2384678	TKK012	Kokstad FET College Reticulation	Cl2 (F) OS*	1.20	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

25-Apr-25	2384678	TKK012	Kokstad FET College Reticulation	Cl ₂ (T) OS*	1.42	-	mg Cl ₂ /L
25-Apr-25	2384679	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2384678	TKK012	Kokstad FET College Reticulation	Coll Time OS*	07:29	-	-
25-Apr-25	2384679	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2384679	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2384678	TKK012	Kokstad FET College Reticulation	pH OS*	7.30	-	-
25-Apr-25	2384678	TKK012	Kokstad FET College Reticulation	Temperature OS*	18.5	-	°C
25-Apr-25	2384681	TKK012	Kokstad FET College Reticulation	Turbidity	0.2	±6.1%	NTU
25-Apr-25	2384709	TNJU002	KwaNjunga Final	Al (AE)	42.9	±7.6%	µg Al/L
25-Apr-25	2384704	TNJU002	KwaNjunga Final	Batch No.*	6248	-	-
25-Apr-25	2384704	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	1.60	-	mg Cl ₂ /L
25-Apr-25	2384704	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	1.82	-	mg Cl ₂ /L
25-Apr-25	2384705	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2384704	TNJU002	KwaNjunga Final	Coll Time OS*	09:34	-	-
25-Apr-25	2384708	TNJU002	KwaNjunga Final	Conductivity	15.7	±1.5%	mS/m
25-Apr-25	2384705	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2384705	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2384704	TNJU002	KwaNjunga Final	pH OS*	7.40	-	-
25-Apr-25	2384704	TNJU002	KwaNjunga Final	Temperature OS*	18.4	-	°C
25-Apr-25	2384707	TNJU002	KwaNjunga Final	Turbidity	0.7	±6.1%	NTU
25-Apr-25	2384710	TNJU003	KwaNjunga Reticulation	Batch No.*	6248	-	-
25-Apr-25	2384710	TNJU003	KwaNjunga Reticulation	Cl ₂ (F) OS*	0.22	-	mg Cl ₂ /L
25-Apr-25	2384710	TNJU003	KwaNjunga Reticulation	Cl ₂ (T) OS*	0.34	-	mg Cl ₂ /L
25-Apr-25	2384711	TNJU003	KwaNjunga Reticulation	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2384710	TNJU003	KwaNjunga Reticulation	Coll Time OS*	09:27	-	-
25-Apr-25	2384711	TNJU003	KwaNjunga Reticulation	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2384711	TNJU003	KwaNjunga Reticulation	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2384710	TNJU003	KwaNjunga Reticulation	pH OS*	7.40	-	-
25-Apr-25	2384710	TNJU003	KwaNjunga Reticulation	Temperature OS*	18.0	-	°C
25-Apr-25	2384713	TNJU003	KwaNjunga Reticulation	Turbidity	0.6	±6.1%	NTU
25-Apr-25	2383427	TRT002	Rietvlei Final	Batch No.*	6248	-	-
25-Apr-25	2383427	TRT002	Rietvlei Final	Cl ₂ (F) OS*	1.50	-	mg Cl ₂ /L
25-Apr-25	2383427	TRT002	Rietvlei Final	Cl ₂ (T) OS*	1.78	-	mg Cl ₂ /L
25-Apr-25	2383428	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

25-Apr-25	2383427	TRT002	Rietvlei Final	Coll Time OS*	10:29	-	-
25-Apr-25	2383431	TRT002	Rietvlei Final	Conductivity	16.4	±1.5%	mS/m
25-Apr-25	2383428	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2383428	TRT002	Rietvlei Final	HPC 37*	5	±21%	cfu/mL
25-Apr-25	2383427	TRT002	Rietvlei Final	pH OS*	7.20	-	-
25-Apr-25	2383427	TRT002	Rietvlei Final	Temperature OS*	18.9	-	°C
25-Apr-25	2383430	TRT002	Rietvlei Final	Turbidity	4.5	±6.1%	NTU
25-Apr-25	2383432	TRT004	Rietvlei Hospital Reticulation	Batch No.*	6248	-	-
25-Apr-25	2383432	TRT004	Rietvlei Hospital Reticulation	Cl2 (F) OS*	0.28	-	mg Cl2/L
25-Apr-25	2383432	TRT004	Rietvlei Hospital Reticulation	Cl2 (T) OS*	0.36	-	mg Cl2/L
25-Apr-25	2383433	TRT004	Rietvlei Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
25-Apr-25	2383432	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	10:44	-	-
25-Apr-25	2383435	TRT004	Rietvlei Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Apr-25	2383436	TRT004	Rietvlei Hospital Reticulation	Conductivity	17.0	±1.5%	mS/m
25-Apr-25	2383433	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
25-Apr-25	2383433	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
25-Apr-25	2383432	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.20	-	-
25-Apr-25	2383432	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	19.9	-	°C
25-Apr-25	2383435	TRT004	Rietvlei Hospital Reticulation	Turbidity	4.1	±6.1%	NTU
28-Apr-25	2385355	TFR002	Franklin Final	Al (AE)	291	±7.6%	µg Al/L
28-Apr-25	2385350	TFR002	Franklin Final	Batch No.*	6248	-	-
28-Apr-25	2385350	TFR002	Franklin Final	Cl2 (F) OS*	0.56	-	mg Cl2/L
28-Apr-25	2385350	TFR002	Franklin Final	Cl2 (T) OS*	0.82	-	mg Cl2/L
28-Apr-25	2385351	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
28-Apr-25	2385351	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
28-Apr-25	2385350	TFR002	Franklin Final	Coll Time OS*	08:00	-	-
28-Apr-25	2385354	TFR002	Franklin Final	Conductivity	16.2	±1.5%	mS/m
28-Apr-25	2385351	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
28-Apr-25	2385351	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
28-Apr-25	2385350	TFR002	Franklin Final	pH OS*	7.40	-	-
28-Apr-25	2385350	TFR002	Franklin Final	Temperature OS*	14.3	-	°C
28-Apr-25	2385353	TFR002	Franklin Final	Turbidity	1.6	±6.1%	NTU
28-Apr-25	2386760	TIB002	Ibisi Final	Al (AE)	960	±7.6%	µg Al/L
28-Apr-25	2386755	TIB002	Ibisi Final	Batch No.*	6248	-	-
28-Apr-25	2386755	TIB002	Ibisi Final	Cl2 (F) OS*	1.04	-	mg Cl2/L
28-Apr-25	2386755	TIB002	Ibisi Final	Cl2 (T) OS*	1.17	-	mg Cl2/L
28-Apr-25	2386756	TIB002	Ibisi Final	Coliforms*	2	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

28-Apr-25	2386756	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
28-Apr-25	2386755	TIB002	Ibisi Final	Coll Time OS*	09:41	-	-
28-Apr-25	2386759	TIB002	Ibisi Final	Conductivity	8.72	±1.5%	mS/m
28-Apr-25	2386756	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
28-Apr-25	2386756	TIB002	Ibisi Final	HPC 37*	29	±21%	cfu/mL
28-Apr-25	2386755	TIB002	Ibisi Final	pH OS*	7.60	-	-
28-Apr-25	2386755	TIB002	Ibisi Final	Temperature OS*	17.4	-	°C
28-Apr-25	2386758	TIB002	Ibisi Final	Turbidity	12.1	±6.1%	NTU
28-Apr-25	2387293	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
28-Apr-25	2387288	TKK002	Kokstad Final	Batch No.*	6248	-	-
28-Apr-25	2387288	TKK002	Kokstad Final	Cl2 (F) OS*	0.56	-	mg Cl2/L
28-Apr-25	2387288	TKK002	Kokstad Final	Cl2 (T) OS*	0.78	-	mg Cl2/L
28-Apr-25	2387289	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
28-Apr-25	2387289	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
28-Apr-25	2387288	TKK002	Kokstad Final	Coll Time OS*	08:12	-	-
28-Apr-25	2387292	TKK002	Kokstad Final	Conductivity	8.69	±1.5%	mS/m
28-Apr-25	2387289	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
28-Apr-25	2387289	TKK002	Kokstad Final	HPC 37*	0	±21%	cfu/mL
28-Apr-25	2387288	TKK002	Kokstad Final	pH OS*	7.60	-	-
28-Apr-25	2387288	TKK002	Kokstad Final	Temperature OS*	20.1	-	°C
28-Apr-25	2387291	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
28-Apr-25	2387331	TNJU002	KwaNjunga Final	Al (AE)	69.5	±7.6%	µg Al/L
28-Apr-25	2387326	TNJU002	KwaNjunga Final	Batch No.*	6248	-	-
28-Apr-25	2387326	TNJU002	KwaNjunga Final	Cl2 (F) OS*	0.80	-	mg Cl2/L
28-Apr-25	2387326	TNJU002	KwaNjunga Final	Cl2 (T) OS*	0.99	-	mg Cl2/L
28-Apr-25	2387327	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
28-Apr-25	2387326	TNJU002	KwaNjunga Final	Coll Time OS*	07:27	-	-
28-Apr-25	2387330	TNJU002	KwaNjunga Final	Conductivity	15.7	±1.5%	mS/m
28-Apr-25	2387327	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
28-Apr-25	2387327	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
28-Apr-25	2387326	TNJU002	KwaNjunga Final	pH OS*	7.50	-	-
28-Apr-25	2387326	TNJU002	KwaNjunga Final	Temperature OS*	17.2	-	°C
28-Apr-25	2387329	TNJU002	KwaNjunga Final	Turbidity	0.6	±6.1%	NTU
29-Apr-25	2386393	TMZ002	Umzimkhulu Final	Al (AE)	374	±7.6%	µg Al/L
29-Apr-25	2386388	TMZ002	Umzimkhulu Final	Batch No.*	6248	-	-
29-Apr-25	2386388	TMZ002	Umzimkhulu Final	Cl2 (F) OS*	0.08	-	mg Cl2/L
29-Apr-25	2386388	TMZ002	Umzimkhulu Final	Cl2 (T) OS*	0.15	-	mg Cl2/L
29-Apr-25	2386389	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
29-Apr-25	2386389	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
29-Apr-25	2386388	TMZ002	Umzimkhulu Final	Coll Time OS*	10:24	-	-
29-Apr-25	2386392	TMZ002	Umzimkhulu Final	Conductivity	8.20	±1.5%	mS/m
29-Apr-25	2386389	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

29-Apr-25	2386389	TMZ002	Umzimkhulu Final	HPC 37*	23	±21%	cfu/mL
29-Apr-25	2386388	TMZ002	Umzimkhulu Final	pH OS*	7.20	-	-
29-Apr-25	2386388	TMZ002	Umzimkhulu Final	Temperature OS*	21.1	-	°C
29-Apr-25	2386391	TMZ002	Umzimkhulu Final	Turbidity	4.2	±6.1%	NTU
29-Apr-25	2386404	TNO002	Nokweja Final	Al (AE)	264	±7.6%	µg Al/L
29-Apr-25	2386399	TNO002	Nokweja Final	Batch No.*	6248	-	-
29-Apr-25	2386399	TNO002	Nokweja Final	Cl2 (F) OS*	0.76	-	mg Cl2/L
29-Apr-25	2386399	TNO002	Nokweja Final	Cl2 (T) OS*	0.86	-	mg Cl2/L
29-Apr-25	2386400	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
29-Apr-25	2386400	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
29-Apr-25	2386399	TNO002	Nokweja Final	Coll Time OS*	10:43	-	-
29-Apr-25	2386403	TNO002	Nokweja Final	Conductivity	8.73	±1.5%	mS/m
29-Apr-25	2386400	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
29-Apr-25	2386400	TNO002	Nokweja Final	HPC 37*	16	±21%	cfu/mL
29-Apr-25	2386399	TNO002	Nokweja Final	pH OS*	7.00	-	-
29-Apr-25	2386399	TNO002	Nokweja Final	Temperature OS*	19.1	-	°C
29-Apr-25	2386402	TNO002	Nokweja Final	Turbidity	4.2	±6.1%	NTU
29-Apr-25	2385422	TQU002	Mnqumeni Final	Batch No.*	6248	-	-
29-Apr-25	2385422	TQU002	Mnqumeni Final	Cl2 (F) OS*	0.58	-	mg Cl2/L
29-Apr-25	2385422	TQU002	Mnqumeni Final	Cl2 (T) OS*	0.74	-	mg Cl2/L
29-Apr-25	2385423	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
29-Apr-25	2385422	TQU002	Mnqumeni Final	Coll Time OS*	07:30	-	-
29-Apr-25	2385426	TQU002	Mnqumeni Final	Conductivity	11.1	±1.5%	mS/m
29-Apr-25	2385423	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
29-Apr-25	2385423	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
29-Apr-25	2385422	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
29-Apr-25	2385422	TQU002	Mnqumeni Final	Temperature OS*	19.9	-	°C
29-Apr-25	2385425	TQU002	Mnqumeni Final	Turbidity	0.3	±6.1%	NTU
29-Apr-25	2385437	TSQ002	Esiqanduleni Final	Al (AE)	88.7	±7.6%	µg Al/L
29-Apr-25	2385432	TSQ002	Esiqanduleni Final	Batch No.*	6248	-	-
29-Apr-25	2385432	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	1.27	-	mg Cl2/L
29-Apr-25	2385432	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.38	-	mg Cl2/L
29-Apr-25	2385433	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
29-Apr-25	2385432	TSQ002	Esiqanduleni Final	Coll Time OS*	07:00	-	-
29-Apr-25	2385436	TSQ002	Esiqanduleni Final	Conductivity	11.2	±1.5%	mS/m
29-Apr-25	2385433	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
29-Apr-25	2385433	TSQ002	Esiqanduleni Final	HPC 37*	2	±21%	cfu/mL
29-Apr-25	2385432	TSQ002	Esiqanduleni Final	pH OS*	7.30	-	-
29-Apr-25	2385432	TSQ002	Esiqanduleni Final	Temperature OS*	18.1	-	°C
29-Apr-25	2385435	TSQ002	Esiqanduleni Final	Turbidity	0.9	±6.1%	NTU
29-Apr-25	2386415	TWA002	Washbank Final	Al (AE)	800	±7.6%	µg Al/L
29-Apr-25	2386410	TWA002	Washbank Final	Batch No.*	6248	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

29-Apr-25	2386410	TWA002	Washbank Final	Cl2 (F) OS*	0.05	-	mg Cl2/L
29-Apr-25	2386410	TWA002	Washbank Final	Cl2 (T) OS*	0.08	-	mg Cl2/L
29-Apr-25	2386411	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
29-Apr-25	2386410	TWA002	Washbank Final	Coll Time OS*	09:33	-	-
29-Apr-25	2386414	TWA002	Washbank Final	Conductivity	7.80	±1.5%	mS/m
29-Apr-25	2386411	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
29-Apr-25	2386411	TWA002	Washbank Final	HPC 37*	1	±21%	cfu/mL
29-Apr-25	2386410	TWA002	Washbank Final	pH OS*	7.40	-	-
29-Apr-25	2386410	TWA002	Washbank Final	Temperature OS*	18.2	-	°C
29-Apr-25	2386413	TWA002	Washbank Final	Turbidity	3.5	±6.1%	NTU
30-Apr-25	2385931	TBU002	Bulwer Final	Batch No.*	6248	-	-
30-Apr-25	2385931	TBU002	Bulwer Final	Cl2 (F) OS*	0.52	-	mg Cl2/L
30-Apr-25	2385931	TBU002	Bulwer Final	Cl2 (T) OS*	0.70	-	mg Cl2/L
30-Apr-25	2385932	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
30-Apr-25	2385931	TBU002	Bulwer Final	Coll Time OS*	09:00	-	-
30-Apr-25	2385935	TBU002	Bulwer Final	Conductivity	4.98	±1.5%	mS/m
30-Apr-25	2385932	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
30-Apr-25	2385932	TBU002	Bulwer Final	HPC 37*	5	±21%	cfu/mL
30-Apr-25	2385931	TBU002	Bulwer Final	pH OS*	7.30	-	-
30-Apr-25	2385931	TBU002	Bulwer Final	Temperature OS*	23.6	-	°C
30-Apr-25	2385934	TBU002	Bulwer Final	Turbidity	4.8	±6.1%	NTU
30-Apr-25	2385946	TCR002	Creighton Final	Al (AE)	229	±7.6%	µg Al/L
30-Apr-25	2385941	TCR002	Creighton Final	Batch No.*	6248	-	-
30-Apr-25	2385941	TCR002	Creighton Final	Cl2 (F) OS*	1.30	-	mg Cl2/L
30-Apr-25	2385941	TCR002	Creighton Final	Cl2 (T) OS*	1.42	-	mg Cl2/L
30-Apr-25	2385942	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
30-Apr-25	2385941	TCR002	Creighton Final	Coll Time OS*	07:28	-	-
30-Apr-25	2385945	TCR002	Creighton Final	Conductivity	8.54	±1.5%	mS/m
30-Apr-25	2385942	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
30-Apr-25	2385942	TCR002	Creighton Final	HPC 37*	0	±21%	cfu/mL
30-Apr-25	2385941	TCR002	Creighton Final	pH OS*	7.40	-	-
30-Apr-25	2385941	TCR002	Creighton Final	Temperature OS*	19.2	-	°C
30-Apr-25	2385944	TCR002	Creighton Final	Turbidity	2.3	±6.1%	NTU
30-Apr-25	2385965	TMAN002	Mangwaneni Final	Batch No.*	6248	-	-
30-Apr-25	2385965	TMAN002	Mangwaneni Final	Cl2 (F) OS*	0.89	-	mg Cl2/L
30-Apr-25	2385965	TMAN002	Mangwaneni Final	Cl2 (T) OS*	1.04	-	mg Cl2/L
30-Apr-25	2385966	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
30-Apr-25	2385965	TMAN002	Mangwaneni Final	Coll Time OS*	09:36	-	-
30-Apr-25	2385969	TMAN002	Mangwaneni Final	Conductivity	10.3	±1.5%	mS/m
30-Apr-25	2385966	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
30-Apr-25	2385966	TMAN002	Mangwaneni Final	HPC 37*	4	±21%	cfu/mL
30-Apr-25	2385965	TMAN002	Mangwaneni Final	pH OS*	7.40	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

30-Apr-25	2385965	TMAN002	Mangwaneni Final	Temperature OS*	16.6	-	°C
30-Apr-25	2385968	TMAN002	Mangwaneni Final	Turbidity	5.7	±6.1%	NTU
30-Apr-25	2385974	TMQA002	Mqatsheni Final	Batch No.*	6248	-	-
30-Apr-25	2385974	TMQA002	Mqatsheni Final	Cl2 (F) OS*	0.86	-	mg Cl2/L
30-Apr-25	2385974	TMQA002	Mqatsheni Final	Cl2 (T) OS*	0.92	-	mg Cl2/L
30-Apr-25	2385975	TMQA002	Mqatsheni Final	Coliforms*	12	±15%	MPN/100mL
30-Apr-25	2385974	TMQA002	Mqatsheni Final	Coll Time OS*	07:55	-	-
30-Apr-25	2385978	TMQA002	Mqatsheni Final	Conductivity	26.8	±1.5%	mS/m
30-Apr-25	2385975	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
30-Apr-25	2385975	TMQA002	Mqatsheni Final	HPC 37*	3	±21%	cfu/mL
30-Apr-25	2385974	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
30-Apr-25	2385974	TMQA002	Mqatsheni Final	Temperature OS*	18.5	-	°C
30-Apr-25	2385977	TMQA002	Mqatsheni Final	Turbidity	1.0	±6.1%	NTU
30-Apr-25	2385989	TRV002	Riverside Final	Al (AE)	56.2	±7.6%	µg Al/L
30-Apr-25	2385984	TRV002	Riverside Final	Batch No.*	6248	-	-
30-Apr-25	2385984	TRV002	Riverside Final	Cl2 (F) OS*	1.20	-	mg Cl2/L
30-Apr-25	2385984	TRV002	Riverside Final	Cl2 (T) OS*	1.36	-	mg Cl2/L
30-Apr-25	2385985	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
30-Apr-25	2385985	TRV002	Riverside Final	Coliphages*	0	±8%	PFU/10ml
30-Apr-25	2385984	TRV002	Riverside Final	Coll Time OS*	08:00	-	-
30-Apr-25	2385988	TRV002	Riverside Final	Conductivity	16.0	±1.5%	mS/m
30-Apr-25	2385985	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
30-Apr-25	2385985	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
30-Apr-25	2385984	TRV002	Riverside Final	pH OS*	7.40	-	-
30-Apr-25	2385984	TRV002	Riverside Final	Temperature OS*	20.0	-	°C
30-Apr-25	2385987	TRV002	Riverside Final	Turbidity	0.5	±6.1%	NTU
30-Apr-25	2386000	TST002	St Appollinaris Final	Al (AE)	486	±7.6%	µg Al/L
30-Apr-25	2385995	TST002	St Appollinaris Final	Batch No.*	6248	-	-
30-Apr-25	2385995	TST002	St Appollinaris Final	Cl2 (F) OS*	0.66	-	mg Cl2/L
30-Apr-25	2385995	TST002	St Appollinaris Final	Cl2 (T) OS*	0.81	-	mg Cl2/L
30-Apr-25	2385996	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
30-Apr-25	2385995	TST002	St Appollinaris Final	Coll Time OS*	08:30	-	-
30-Apr-25	2385999	TST002	St Appollinaris Final	Conductivity	7.94	±1.5%	mS/m
30-Apr-25	2385996	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
30-Apr-25	2385996	TST002	St Appollinaris Final	HPC 37*	0	±21%	cfu/mL
30-Apr-25	2385995	TST002	St Appollinaris Final	pH OS*	7.20	-	-
30-Apr-25	2385995	TST002	St Appollinaris Final	Temperature OS*	18.8	-	°C
30-Apr-25	2385998	TST002	St Appollinaris Final	Turbidity	4.9	±6.1%	NTU
30-Apr-25	2386011	TUN002	Underberg Final	Al (AE)	52.2	±7.6%	µg Al/L
30-Apr-25	2386006	TUN002	Underberg Final	Batch No.*	6248	-	-
30-Apr-25	2386006	TUN002	Underberg Final	Cl2 (F) OS*	0.50	-	mg Cl2/L
30-Apr-25	2386006	TUN002	Underberg Final	Cl2 (T) OS*	0.66	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

30-Apr-25	2386007	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
30-Apr-25	2386006	TUN002	Underberg Final	Coll Time OS*	08:39	-	-
30-Apr-25	2386010	TUN002	Underberg Final	Conductivity	5.95	±1.5%	mS/m
30-Apr-25	2386007	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
30-Apr-25	2386007	TUN002	Underberg Final	HPC 37*	0	±21%	cfu/mL
30-Apr-25	2386006	TUN002	Underberg Final	pH OS*	7.60	-	-
30-Apr-25	2386006	TUN002	Underberg Final	Temperature OS*	15.7	-	°C
30-Apr-25	2386009	TUN002	Underberg Final	Turbidity	0.5	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)