

Date: 06 June 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

MAY 2025 UNTREATED WATER (RAW) RESULTS

Please find May 2025 Untreated Water (Raw) results tabulated below for samples received during May 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
05-May-25	2389317	TFR001	Franklin Raw	Al (AE)	248	±7.6%	µg Al/L
05-May-25	2389314	TFR001	Franklin Raw	Coliforms*	1120	±22%	MPN/100mL
05-May-25	2389314	TFR001	Franklin Raw	Coliphages*	40	±8%	PFU/10ml
05-May-25	2389313	TFR001	Franklin Raw	Coll Time OS*	08:15	-	-
05-May-25	2389316	TFR001	Franklin Raw	Conductivity	11.2	±1.5%	mS/m
05-May-25	2389314	TFR001	Franklin Raw	E.coli*	161	±21%	MPN/100mL
05-May-25	2389313	TFR001	Franklin Raw	pH OS*	7.10	-	-
05-May-25	2389313	TFR001	Franklin Raw	Temperature OS*	13.8	-	°C
05-May-25	2389315	TFR001	Franklin Raw	Turbidity	11.6	±6.1%	NTU
05-May-25	2389349	TKK001	Kokstad River Raw	Al (AE)	228	±7.6%	µg Al/L
05-May-25	2389346	TKK001	Kokstad River Raw	Coliforms*	210	±22%	MPN/100mL
05-May-25	2389346	TKK001	Kokstad River Raw	Coliphages*	2	±8%	PFU/10ml
05-May-25	2389345	TKK001	Kokstad River Raw	Coll Time OS*	09:20	-	-
05-May-25	2389347	TKK001	Kokstad River Raw	Colour	5.80	±6.5%	mg Pt-Co/L
05-May-25	2389348	TKK001	Kokstad River Raw	Conductivity	8.13	±1.5%	mS/m
05-May-25	2389346	TKK001	Kokstad River Raw	E.coli*	1	±21%	MPN/100mL
05-May-25	2389349	TKK001	Kokstad River Raw	Fe (AE)	0.77	±5.4%	mg Fe/L
05-May-25	2389349	TKK001	Kokstad River Raw	Mn (AE)	<0.01	±6.2%	mg Mn/L
05-May-25	2389347	TKK001	Kokstad River Raw	Odour*	Nil	-	-
05-May-25	2389345	TKK001	Kokstad River Raw	pH OS*	7.30	-	-
05-May-25	2389345	TKK001	Kokstad River Raw	Temperature OS*	17.5	-	°C
05-May-25	2389347	TKK001	Kokstad River Raw	Turbidity	11.6	±6.1%	NTU
05-May-25	2389360	TKK003	Kokstad Crystal Spring Raw	Al (AE)	317	±7.6%	µg Al/L
05-May-25	2389357	TKK003	Kokstad Crystal Spring Raw	Coliforms*	770	±22%	MPN/100mL
05-May-25	2389357	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
05-May-25	2389356	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	09:19	-	-
05-May-25	2389358	TKK003	Kokstad Crystal Spring Raw	Colour	9.10	±6.5%	mg Pt-Co/L
05-May-25	2389359	TKK003	Kokstad Crystal Spring Raw	Conductivity	7.93	±1.5%	mS/m
05-May-25	2389357	TKK003	Kokstad Crystal Spring Raw	E.coli*	7	±21%	MPN/100mL
05-May-25	2389360	TKK003	Kokstad Crystal Spring Raw	Fe (AE)	0.68	±5.4%	mg Fe/L
05-May-25	2389358	TKK003	Kokstad Crystal Spring Raw	Odour*	Nil	-	-
05-May-25	2389356	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.30	-	-
05-May-25	2389356	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	17.6	-	°C
05-May-25	2389358	TKK003	Kokstad Crystal Spring Raw	Turbidity	10.6	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

06-May-25	2390019	TQU001	Mnqumeni Raw	Coliforms*	1986	±22%	MPN/100mL
06-May-25	2390018	TQU001	Mnqumeni Raw	Coll Time OS*	08:23	-	-
06-May-25	2390020	TQU001	Mnqumeni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
06-May-25	2390021	TQU001	Mnqumeni Raw	Conductivity	11.1	±1.5%	mS/m
06-May-25	2390019	TQU001	Mnqumeni Raw	E.coli*	62	±21%	MPN/100mL
06-May-25	2390020	TQU001	Mnqumeni Raw	Odour*	Nil	-	-
06-May-25	2390018	TQU001	Mnqumeni Raw	pH OS*	7.90	-	-
06-May-25	2390018	TQU001	Mnqumeni Raw	Temperature OS*	19.0	-	°C
06-May-25	2390020	TQU001	Mnqumeni Raw	Turbidity	24.7	±6.1%	NTU
06-May-25	2390032	TSQ001	Esiqanduleni Raw	Al (AE)	264	±7.6%	µg Al/L
06-May-25	2390029	TSQ001	Esiqanduleni Raw	Coliforms*	1986	±22%	MPN/100mL
06-May-25	2390029	TSQ001	Esiqanduleni Raw	Coliphages*	1	±8%	PFU/10ml
06-May-25	2390028	TSQ001	Esiqanduleni Raw	Coll Time OS*	07:30	-	-
06-May-25	2390031	TSQ001	Esiqanduleni Raw	Conductivity	11.5	±1.5%	mS/m
06-May-25	2390029	TSQ001	Esiqanduleni Raw	E.coli*	20	±21%	MPN/100mL
06-May-25	2390028	TSQ001	Esiqanduleni Raw	pH OS*	7.40	-	-
06-May-25	2390028	TSQ001	Esiqanduleni Raw	Temperature OS*	17.3	-	°C
06-May-25	2390030	TSQ001	Esiqanduleni Raw	Turbidity	7.7	±6.1%	NTU
07-May-25	2390609	TBU001	Bulwer Raw	Al (AE)	321	±7.6%	µg Al/L
07-May-25	2390606	TBU001	Bulwer Raw	Coliforms*	649	±22%	MPN/100mL
07-May-25	2390605	TBU001	Bulwer Raw	Coll Time OS*	08:58	-	-
07-May-25	2390607	TBU001	Bulwer Raw	Colour	1.80	±6.5%	mg Pt-Co/L
07-May-25	2390608	TBU001	Bulwer Raw	Conductivity	5.20	±1.5%	mS/m
07-May-25	2390606	TBU001	Bulwer Raw	E.coli*	13	±21%	MPN/100mL
07-May-25	2390609	TBU001	Bulwer Raw	Fe (AE)	0.46	±5.4%	mg Fe/L
07-May-25	2390607	TBU001	Bulwer Raw	Odour*	Nil	-	-
07-May-25	2390605	TBU001	Bulwer Raw	pH OS*	7.30	-	-
07-May-25	2390605	TBU001	Bulwer Raw	Temperature OS*	22.9	-	°C
07-May-25	2390607	TBU001	Bulwer Raw	Turbidity	7.2	±6.1%	NTU
07-May-25	2390625	TCR001	Creighton Raw	Al (AE)	195	±7.6%	µg Al/L
07-May-25	2390622	TCR001	Creighton Raw	Coliforms*	138	±22%	MPN/100mL
07-May-25	2390621	TCR001	Creighton Raw	Coll Time OS*	06:38	-	-
07-May-25	2390623	TCR001	Creighton Raw	Colour	1.50	±6.5%	mg Pt-Co/L
07-May-25	2390624	TCR001	Creighton Raw	Conductivity	6.85	±1.5%	mS/m
07-May-25	2390622	TCR001	Creighton Raw	E.coli*	5	±21%	MPN/100mL
07-May-25	2390625	TCR001	Creighton Raw	Fe (AE)	0.17	±5.4%	mg Fe/L
07-May-25	2390625	TCR001	Creighton Raw	Mn (AE)	<0.01	±6.2%	mg Mn/L
07-May-25	2390623	TCR001	Creighton Raw	Odour*	Nil	-	-
07-May-25	2390621	TCR001	Creighton Raw	pH OS*	7.20	-	-
07-May-25	2390621	TCR001	Creighton Raw	Temperature OS*	16.6	-	°C
07-May-25	2390623	TCR001	Creighton Raw	Turbidity	4.6	±6.1%	NTU
07-May-25	2390643	THL001	Hlanganani Raw	Coliforms*	687	±22%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

07-May-25	2390642	THL001	Hlanganani Raw	Coll Time OS*	10:31	-	-
07-May-25	2390644	THL001	Hlanganani Raw	Colour	2.80	±6.5%	mg Pt-Co/L
07-May-25	2390645	THL001	Hlanganani Raw	Conductivity	7.91	±1.5%	mS/m
07-May-25	2390643	THL001	Hlanganani Raw	E.coli*	73	±21%	MPN/100mL
07-May-25	2390644	THL001	Hlanganani Raw	Odour*	Nil	-	-
07-May-25	2390642	THL001	Hlanganani Raw	pH OS*	7.20	-	-
07-May-25	2390642	THL001	Hlanganani Raw	Temperature OS*	26.3	-	°C
07-May-25	2390644	THL001	Hlanganani Raw	Turbidity	8.2	±6.1%	NTU
07-May-25	2390670	TMAN001	Mangwaneni Raw	Al (AE)	236	±7.6%	µg Al/L
07-May-25	2390667	TMAN001	Mangwaneni Raw	Coliforms*	1203	±22%	MPN/100mL
07-May-25	2390666	TMAN001	Mangwaneni Raw	Coll Time OS*	10:01	-	-
07-May-25	2390668	TMAN001	Mangwaneni Raw	Colour	2.70	±6.5%	mg Pt-Co/L
07-May-25	2390669	TMAN001	Mangwaneni Raw	Conductivity	8.38	±1.5%	mS/m
07-May-25	2390667	TMAN001	Mangwaneni Raw	E.coli*	49	±21%	MPN/100mL
07-May-25	2390670	TMAN001	Mangwaneni Raw	Fe (AE)	0.27	±5.4%	mg Fe/L
07-May-25	2390666	TMAN001	Mangwaneni Raw	pH OS*	7.50	-	-
07-May-25	2390666	TMAN001	Mangwaneni Raw	Temperature OS*	22.1	-	°C
07-May-25	2390668	TMAN001	Mangwaneni Raw	Turbidity	5.8	±6.1%	NTU
07-May-25	2390681	TMQA001	Mqatsheni Raw	Al (AE)	43.6	±7.6%	µg Al/L
07-May-25	2390678	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL
07-May-25	2390677	TMQA001	Mqatsheni Raw	Coll Time OS*	07:35	-	-
07-May-25	2390679	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
07-May-25	2390680	TMQA001	Mqatsheni Raw	Conductivity	24.6	±1.5%	mS/m
07-May-25	2390678	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
07-May-25	2390681	TMQA001	Mqatsheni Raw	Fe (AE)	<0.02	±5.4%	mg Fe/L
07-May-25	2390679	TMQA001	Mqatsheni Raw	Odour*	Nil	-	-
07-May-25	2390677	TMQA001	Mqatsheni Raw	pH OS*	9.00	-	-
07-May-25	2390677	TMQA001	Mqatsheni Raw	Temperature OS*	14.7	-	°C
07-May-25	2390679	TMQA001	Mqatsheni Raw	Turbidity	0.4	±6.1%	NTU
07-May-25	2390697	TRV001	Riversside Raw	Al (AE)	3739	±7.6%	µg Al/L
07-May-25	2390694	TRV001	Riversside Raw	Coliforms*	52	±22%	MPN/100mL
07-May-25	2390693	TRV001	Riversside Raw	Coll Time OS*	07:35	-	-
07-May-25	2390695	TRV001	Riversside Raw	Colour	9.20	±6.5%	mg Pt-Co/L
07-May-25	2390696	TRV001	Riversside Raw	Conductivity	6.80	±1.5%	mS/m
07-May-25	2390694	TRV001	Riversside Raw	E.coli*	2	±21%	MPN/100mL
07-May-25	2390697	TRV001	Riversside Raw	Fe (AE)	0.41	±5.4%	mg Fe/L
07-May-25	2390695	TRV001	Riversside Raw	Odour*	Nil	-	-
07-May-25	2390693	TRV001	Riversside Raw	pH OS*	7.40	-	-
07-May-25	2390693	TRV001	Riversside Raw	Temperature OS*	17.1	-	°C
07-May-25	2390695	TRV001	Riversside Raw	Turbidity	6.3	±6.1%	NTU
07-May-25	2390712	TST001	St Appollinaris Raw	Al (AE)	204	±7.6%	µg Al/L
07-May-25	2390709	TST001	St Appollinaris Raw	Coliforms*	411	±22%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

07-May-25	2390708	TST001	St Appollinaris Raw	Coll Time OS*	08:05	-	-
07-May-25	2390710	TST001	St Appollinaris Raw	Colour	5.30	±6.5%	mg Pt-Co/L
07-May-25	2390711	TST001	St Appollinaris Raw	Conductivity	7.02	±1.5%	mS/m
07-May-25	2390709	TST001	St Appollinaris Raw	E.coli*	21	±21%	MPN/100mL
07-May-25	2390712	TST001	St Appollinaris Raw	Fe (AE)	0.35	±5.4%	mg Fe/L
07-May-25	2390710	TST001	St Appollinaris Raw	Odour*	Nil	-	-
07-May-25	2390708	TST001	St Appollinaris Raw	pH OS*	7.30	-	-
07-May-25	2390708	TST001	St Appollinaris Raw	Temperature OS*	19.8	-	°C
07-May-25	2390710	TST001	St Appollinaris Raw	Turbidity	3.7	±6.1%	NTU
07-May-25	2390723	TUN001	Underberg Raw	Al (AE)	79.7	±7.6%	µg Al/L
07-May-25	2390720	TUN001	Underberg Raw	Coliforms*	649	±22%	MPN/100mL
07-May-25	2390720	TUN001	Underberg Raw	Coliphages*	4	±8%	PFU/10ml
07-May-25	2390719	TUN001	Underberg Raw	Coll Time OS*	09:11	-	-
07-May-25	2390721	TUN001	Underberg Raw	Colour	1.20	±6.5%	mg Pt-Co/L
07-May-25	2390722	TUN001	Underberg Raw	Conductivity	5.82	±1.5%	mS/m
07-May-25	2390720	TUN001	Underberg Raw	E.coli*	326	±21%	MPN/100mL
07-May-25	2390723	TUN001	Underberg Raw	Fe (AE)	0.19	±5.4%	mg Fe/L
07-May-25	2390721	TUN001	Underberg Raw	Odour*	Nil	-	-
07-May-25	2390719	TUN001	Underberg Raw	pH OS*	7.40	-	-
07-May-25	2390719	TUN001	Underberg Raw	Temperature OS*	14.5	-	°C
07-May-25	2390721	TUN001	Underberg Raw	Turbidity	1.7	±6.1%	NTU
08-May-25	2391410	TMZ001	Umzimkhulu Raw	Al (AE)	545	±7.6%	µg Al/L
08-May-25	2391407	TMZ001	Umzimkhulu Raw	Coliforms*	921	±22%	MPN/100mL
08-May-25	2391407	TMZ001	Umzimkhulu Raw	Coliphages*	15	±8%	PFU/10ml
08-May-25	2391406	TMZ001	Umzimkhulu Raw	Coll Time OS*	08:08	-	-
08-May-25	2391408	TMZ001	Umzimkhulu Raw	Colour	1.20	±6.5%	mg Pt-Co/L
08-May-25	2391409	TMZ001	Umzimkhulu Raw	Conductivity	8.19	±1.5%	mS/m
08-May-25	2391407	TMZ001	Umzimkhulu Raw	E.coli*	57	±21%	MPN/100mL
08-May-25	2391410	TMZ001	Umzimkhulu Raw	Fe (AE)	0.63	±5.4%	mg Fe/L
08-May-25	2391408	TMZ001	Umzimkhulu Raw	Odour*	Nil	-	-
08-May-25	2391406	TMZ001	Umzimkhulu Raw	pH OS*	7.50	-	-
08-May-25	2391406	TMZ001	Umzimkhulu Raw	Temperature OS*	15.8	-	°C
08-May-25	2391408	TMZ001	Umzimkhulu Raw	Turbidity	12.8	±6.1%	NTU
08-May-25	2391437	TNO001	Nokweja Raw	Al (AE)	554	±7.6%	µg Al/L
08-May-25	2391434	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
08-May-25	2391434	TNO001	Nokweja Raw	Coliphages*	33	±8%	PFU/10ml
08-May-25	2391433	TNO001	Nokweja Raw	Coll Time OS*	08:05	-	-
08-May-25	2391435	TNO001	Nokweja Raw	Colour	4.40	±6.5%	mg Pt-Co/L
08-May-25	2391436	TNO001	Nokweja Raw	Conductivity	8.46	±1.5%	mS/m
08-May-25	2391434	TNO001	Nokweja Raw	E.coli*	921	±21%	MPN/100mL
08-May-25	2391437	TNO001	Nokweja Raw	Fe (AE)	0.50	±5.4%	mg Fe/L
08-May-25	2391435	TNO001	Nokweja Raw	Odour*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

08-May-25	2391433	TNO001	Nokweja Raw	pH OS*	7.20	-	-
08-May-25	2391433	TNO001	Nokweja Raw	Temperature OS*	20.0	-	°C
08-May-25	2391435	TNO001	Nokweja Raw	Turbidity	10.6	±6.1%	NTU
08-May-25	2391456	TWA001	Washbank Raw	Al (AE)	3673	±7.6%	µg Al/L
08-May-25	2391453	TWA001	Washbank Raw	Coliforms*	1046	±22%	MPN/100mL
08-May-25	2391452	TWA001	Washbank Raw	Coll Time OS*	07:36	-	-
08-May-25	2391455	TWA001	Washbank Raw	Conductivity	7.19	±1.5%	mS/m
08-May-25	2391453	TWA001	Washbank Raw	E.coli*	12	±21%	MPN/100mL
08-May-25	2391454	TWA001	Washbank Raw	Odour*	Nil	-	-
08-May-25	2391452	TWA001	Washbank Raw	pH OS*	7.70	-	-
08-May-25	2391452	TWA001	Washbank Raw	Temperature OS*	14.4	-	°C
08-May-25	2391454	TWA001	Washbank Raw	Turbidity	11.7	±6.1%	NTU
09-May-25	2391771	TIB001	Ibisi Raw	Al (AE)	244	±7.6%	µg Al/L
09-May-25	2391768	TIB001	Ibisi Raw	Coliforms*	2420	±22%	MPN/100mL
09-May-25	2391768	TIB001	Ibisi Raw	Coliphages*	10	±8%	PFU/10ml
09-May-25	2391767	TIB001	Ibisi Raw	Coll Time OS*	06:29	-	-
09-May-25	2391769	TIB001	Ibisi Raw	Colour	1.00	±6.5%	mg Pt-Co/L
09-May-25	2391770	TIB001	Ibisi Raw	Conductivity	8.12	±1.5%	mS/m
09-May-25	2391768	TIB001	Ibisi Raw	E.coli*	93	±21%	MPN/100mL
09-May-25	2391771	TIB001	Ibisi Raw	Fe (AE)	0.88	±5.4%	mg Fe/L
09-May-25	2391769	TIB001	Ibisi Raw	Odour*	Nil	-	-
09-May-25	2391767	TIB001	Ibisi Raw	pH OS*	7.50	-	-
09-May-25	2391767	TIB001	Ibisi Raw	Temperature OS*	17.4	-	°C
09-May-25	2391769	TIB001	Ibisi Raw	Turbidity	23.0	±6.1%	NTU
09-May-25	2391783	TRT001	Rietvlei Raw	Coliforms*	>2420	±22%	MPN/100mL
09-May-25	2391782	TRT001	Rietvlei Raw	Coll Time OS*	08:00	-	-
09-May-25	2391784	TRT001	Rietvlei Raw	Colour	3.20	±6.5%	mg Pt-Co/L
09-May-25	2391785	TRT001	Rietvlei Raw	Conductivity	14.8	±1.5%	mS/m
09-May-25	2391783	TRT001	Rietvlei Raw	E.coli*	194	±21%	MPN/100mL
09-May-25	2391784	TRT001	Rietvlei Raw	Odour*	Nil	-	-
09-May-25	2391782	TRT001	Rietvlei Raw	pH OS*	7.50	-	-
09-May-25	2391782	TRT001	Rietvlei Raw	Temperature OS*	18.1	-	°C
09-May-25	2391784	TRT001	Rietvlei Raw	Turbidity	17.9	±6.1%	NTU
12-May-25	2394983	TFR001	Franklin Raw	Al (AE)	509	±7.6%	µg Al/L
12-May-25	2394980	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
12-May-25	2394980	TFR001	Franklin Raw	Coliphages*	99	±8%	PFU/10ml
12-May-25	2394979	TFR001	Franklin Raw	Coll Time OS*	08:20	-	-
12-May-25	2394982	TFR001	Franklin Raw	Conductivity	10.3	±1.5%	mS/m
12-May-25	2394980	TFR001	Franklin Raw	E.coli*	461	±21%	MPN/100mL
12-May-25	2394979	TFR001	Franklin Raw	pH OS*	7.40	-	-
12-May-25	2394979	TFR001	Franklin Raw	Temperature OS*	11.2	-	°C
12-May-25	2394981	TFR001	Franklin Raw	Turbidity	13.9	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

12-May-25	2395003	TKK001	Kokstad River Raw	AI (AE)	765	±7.6%	µg AI/L
12-May-25	2395000	TKK001	Kokstad River Raw	Coliforms*	153	±22%	MPN/100mL
12-May-25	2395000	TKK001	Kokstad River Raw	Coliphages*	19	±8%	PFU/10ml
12-May-25	2394999	TKK001	Kokstad River Raw	Coll Time OS*	08:35	-	-
12-May-25	2395002	TKK001	Kokstad River Raw	Conductivity	8.42	±1.5%	mS/m
12-May-25	2395000	TKK001	Kokstad River Raw	E.coli*	3	±21%	MPN/100mL
12-May-25	2394999	TKK001	Kokstad River Raw	pH OS*	7.40	-	-
12-May-25	2394999	TKK001	Kokstad River Raw	Temperature OS*	16.3	-	°C
12-May-25	2395001	TKK001	Kokstad River Raw	Turbidity	7.4	±6.1%	NTU
12-May-25	2395014	TKK003	Kokstad Crystal Spring Raw	AI (AE)	501	±7.6%	µg AI/L
12-May-25	2395011	TKK003	Kokstad Crystal Spring Raw	Coliforms*	77	±22%	MPN/100mL
12-May-25	2395011	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
12-May-25	2395010	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	08:55	-	-
12-May-25	2395013	TKK003	Kokstad Crystal Spring Raw	Conductivity	8.21	±1.5%	mS/m
12-May-25	2395011	TKK003	Kokstad Crystal Spring Raw	E.coli*	0	±21%	MPN/100mL
12-May-25	2395010	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.60	-	-
12-May-25	2395010	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	14.4	-	°C
12-May-25	2395012	TKK003	Kokstad Crystal Spring Raw	Turbidity	6.6	±6.1%	NTU
13-May-25	2395626	TQU001	Mnqumeni Raw	Coliforms*	2420	±22%	MPN/100mL
13-May-25	2395625	TQU001	Mnqumeni Raw	Coll Time OS*	07:42	-	-
13-May-25	2395628	TQU001	Mnqumeni Raw	Conductivity	10.9	±1.5%	mS/m
13-May-25	2395626	TQU001	Mnqumeni Raw	E.coli*	63	±21%	MPN/100mL
13-May-25	2395625	TQU001	Mnqumeni Raw	pH OS*	7.90	-	-
13-May-25	2395625	TQU001	Mnqumeni Raw	Temperature OS*	15.7	-	°C
13-May-25	2395627	TQU001	Mnqumeni Raw	Turbidity	12.2	±6.1%	NTU
13-May-25	2395638	TSQ001	Esiqanduleni Raw	AI (AE)	252	±7.6%	µg AI/L
13-May-25	2395635	TSQ001	Esiqanduleni Raw	Coliforms*	1553	±22%	MPN/100mL
13-May-25	2395635	TSQ001	Esiqanduleni Raw	Coliphages*	0	±8%	PFU/10ml
13-May-25	2395634	TSQ001	Esiqanduleni Raw	Coll Time OS*	08:18	-	-
13-May-25	2395637	TSQ001	Esiqanduleni Raw	Conductivity	13.1	±1.5%	mS/m
13-May-25	2395635	TSQ001	Esiqanduleni Raw	E.coli*	15	±21%	MPN/100mL
13-May-25	2395634	TSQ001	Esiqanduleni Raw	pH OS*	7.30	-	-
13-May-25	2395634	TSQ001	Esiqanduleni Raw	Temperature OS*	18.8	-	°C
13-May-25	2395636	TSQ001	Esiqanduleni Raw	Turbidity	4.5	±6.1%	NTU
14-May-25	2396130	TBU001	Bulwer Raw	AI (AE)	317	±7.6%	µg AI/L
14-May-25	2396127	TBU001	Bulwer Raw	Coliforms*	687	±22%	MPN/100mL
14-May-25	2396126	TBU001	Bulwer Raw	Coll Time OS*	10:10	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

14-May-25	2396128	TBU001	Bulwer Raw	Colour	3.70	±6.5%	mg Pt-Co/L
14-May-25	2396129	TBU001	Bulwer Raw	Conductivity	5.28	±1.5%	mS/m
14-May-25	2396127	TBU001	Bulwer Raw	E.coli*	29	±21%	MPN/100mL
14-May-25	2396126	TBU001	Bulwer Raw	pH OS*	7.40	-	-
14-May-25	2396126	TBU001	Bulwer Raw	Temperature OS*	21.4	-	°C
14-May-25	2396128	TBU001	Bulwer Raw	Turbidity	5.9	±6.1%	NTU
14-May-25	2396140	TCR001	Creighton Raw	Al (AE)	124	±7.6%	µg Al/L
14-May-25	2396137	TCR001	Creighton Raw	Coliforms*	122	±22%	MPN/100mL
14-May-25	2396136	TCR001	Creighton Raw	Coll Time OS*	08:10	-	-
14-May-25	2396138	TCR001	Creighton Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
14-May-25	2396139	TCR001	Creighton Raw	Conductivity	6.97	±1.5%	mS/m
14-May-25	2396137	TCR001	Creighton Raw	E.coli*	0	±21%	MPN/100mL
14-May-25	2396136	TCR001	Creighton Raw	pH OS*	7.20	-	-
14-May-25	2396136	TCR001	Creighton Raw	Temperature OS*	17.1	-	°C
14-May-25	2396138	TCR001	Creighton Raw	Turbidity	2.4	±6.1%	NTU
14-May-25	2396148	THL001	Hlanganani Raw	Coliforms*	1120	±22%	MPN/100mL
14-May-25	2396147	THL001	Hlanganani Raw	Coll Time OS*	11:00	-	-
14-May-25	2396150	THL001	Hlanganani Raw	Conductivity	7.94	±1.5%	mS/m
14-May-25	2396148	THL001	Hlanganani Raw	E.coli*	57	±21%	MPN/100mL
14-May-25	2396147	THL001	Hlanganani Raw	pH OS*	7.30	-	-
14-May-25	2396147	THL001	Hlanganani Raw	Temperature OS*	22.0	-	°C
14-May-25	2396149	THL001	Hlanganani Raw	Turbidity	8.8	±6.1%	NTU
14-May-25	2396163	TMAN001	Mangwaneni Raw	Coliforms*	1986	±22%	MPN/100mL
14-May-25	2396162	TMAN001	Mangwaneni Raw	Coll Time OS*	10:58	-	-
14-May-25	2396164	TMAN001	Mangwaneni Raw	Colour	6.60	±6.5%	mg Pt-Co/L
14-May-25	2396165	TMAN001	Mangwaneni Raw	Conductivity	8.49	±1.5%	mS/m
14-May-25	2396163	TMAN001	Mangwaneni Raw	E.coli*	140	±21%	MPN/100mL
14-May-25	2396162	TMAN001	Mangwaneni Raw	pH OS*	7.30	-	-
14-May-25	2396162	TMAN001	Mangwaneni Raw	Temperature OS*	19.1	-	°C
14-May-25	2396164	TMAN001	Mangwaneni Raw	Turbidity	7.1	±6.1%	NTU
14-May-25	2396172	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL
14-May-25	2396171	TMQA001	Mqatsheni Raw	Coll Time OS*	08:35	-	-
14-May-25	2396173	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
14-May-25	2396174	TMQA001	Mqatsheni Raw	Conductivity	29.5	±1.5%	mS/m
14-May-25	2396172	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
14-May-25	2396171	TMQA001	Mqatsheni Raw	pH OS*	8.80	-	-
14-May-25	2396171	TMQA001	Mqatsheni Raw	Temperature OS*	16.7	-	°C
14-May-25	2396173	TMQA001	Mqatsheni Raw	Turbidity	1.2	±6.1%	NTU
14-May-25	2396184	TRV001	Riversside Raw	Al (AE)	6348	±7.6%	µg Al/L
14-May-25	2396181	TRV001	Riversside Raw	Coliforms*	91	±22%	MPN/100mL
14-May-25	2396180	TRV001	Riversside Raw	Coll Time OS*	08:35	-	-
14-May-25	2396182	TRV001	Riversside Raw	Colour	12.4	±6.5%	mg Pt-Co/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

14-May-25	2396183	TRV001	Riversside Raw	Conductivity	7.24	±1.5%	mS/m
14-May-25	2396181	TRV001	Riversside Raw	E.coli*	3	±21%	MPN/100mL
14-May-25	2396180	TRV001	Riversside Raw	pH OS*	7.30	-	-
14-May-25	2396180	TRV001	Riversside Raw	Temperature OS*	20.1	-	°C
14-May-25	2396182	TRV001	Riversside Raw	Turbidity	5.1	±6.1%	NTU
14-May-25	2396195	TST001	St Appollinaris Raw	AI (AE)	142	±7.6%	µg AI/L
14-May-25	2396192	TST001	St Appollinaris Raw	Coliforms*	326	±22%	MPN/100mL
14-May-25	2396191	TST001	St Appollinaris Raw	Coll Time OS*	09:35	-	-
14-May-25	2396194	TST001	St Appollinaris Raw	Conductivity	7.38	±1.5%	mS/m
14-May-25	2396192	TST001	St Appollinaris Raw	E.coli*	28	±21%	MPN/100mL
14-May-25	2396191	TST001	St Appollinaris Raw	pH OS*	7.30	-	-
14-May-25	2396191	TST001	St Appollinaris Raw	Temperature OS*	18.2	-	°C
14-May-25	2396193	TST001	St Appollinaris Raw	Turbidity	3.0	±6.1%	NTU
14-May-25	2396206	TUN001	Underberg Raw	AI (AE)	58.5	±7.6%	µg AI/L
14-May-25	2396203	TUN001	Underberg Raw	Coliforms*	411	±22%	MPN/100mL
14-May-25	2396203	TUN001	Underberg Raw	Coliphages*	9	±8%	PFU/10ml
14-May-25	2396202	TUN001	Underberg Raw	Coll Time OS*	07:11	-	-
14-May-25	2396205	TUN001	Underberg Raw	Conductivity	6.49	±1.5%	mS/m
14-May-25	2396203	TUN001	Underberg Raw	E.coli*	179	±21%	MPN/100mL
14-May-25	2396202	TUN001	Underberg Raw	pH OS*	8.00	-	-
14-May-25	2396202	TUN001	Underberg Raw	Temperature OS*	12.5	-	°C
14-May-25	2396204	TUN001	Underberg Raw	Turbidity	1.4	±6.1%	NTU
15-May-25	2396869	TMZ001	Umzimkhulu Raw	AI (AE)	412	±7.6%	µg AI/L
15-May-25	2396866	TMZ001	Umzimkhulu Raw	Coliforms*	727	±22%	MPN/100mL
15-May-25	2396866	TMZ001	Umzimkhulu Raw	Coliphages*	7	±8%	PFU/10ml
15-May-25	2396865	TMZ001	Umzimkhulu Raw	Coll Time OS*	07:54	-	-
15-May-25	2396868	TMZ001	Umzimkhulu Raw	Conductivity	8.86	±1.5%	mS/m
15-May-25	2396866	TMZ001	Umzimkhulu Raw	E.coli*	54	±21%	MPN/100mL
15-May-25	2396865	TMZ001	Umzimkhulu Raw	pH OS*	7.30	-	-
15-May-25	2396865	TMZ001	Umzimkhulu Raw	Temperature OS*	15.2	-	°C
15-May-25	2396867	TMZ001	Umzimkhulu Raw	Turbidity	9.0	±6.1%	NTU
15-May-25	2396882	TNO001	Nokweja Raw	AI (AE)	412	±7.6%	µg AI/L
15-May-25	2396878	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
15-May-25	2396878	TNO001	Nokweja Raw	Coliphages*	29	±8%	PFU/10ml
15-May-25	2396877	TNO001	Nokweja Raw	Coll Time OS*	08:03	-	-
15-May-25	2396881	TNO001	Nokweja Raw	Conductivity	9.21	±1.5%	mS/m
15-May-25	2396878	TNO001	Nokweja Raw	E.coli*	1553	±21%	MPN/100mL
15-May-25	2396877	TNO001	Nokweja Raw	pH OS*	7.30	-	-
15-May-25	2396877	TNO001	Nokweja Raw	Temperature OS*	16.7	-	°C
15-May-25	2396879	TNO001	Nokweja Raw	Turbidity	7.4	±6.1%	NTU
15-May-25	2396893	TWA001	Washbank Raw	AI (AE)	2083	±7.6%	µg AI/L
15-May-25	2396890	TWA001	Washbank Raw	Coliforms*	727	±22%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

15-May-25	2396889	TWA001	Washbank Raw	Coll Time OS*	07:08	-	-
15-May-25	2396891	TWA001	Washbank Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
15-May-25	2396892	TWA001	Washbank Raw	Conductivity	7.11	±1.5%	mS/m
15-May-25	2396890	TWA001	Washbank Raw	E.coli*	5	±21%	MPN/100mL
15-May-25	2396893	TWA001	Washbank Raw	Fe (AE)	0.35	±5.4%	mg Fe/L
15-May-25	2396889	TWA001	Washbank Raw	pH OS*	7.20	-	-
15-May-25	2396889	TWA001	Washbank Raw	Temperature OS*	13.7	-	°C
15-May-25	2396891	TWA001	Washbank Raw	Turbidity	6.7	±6.1%	NTU
16-May-25	2397110	TIB001	Ibisi Raw	Al (AE)	235	±7.6%	µg Al/L
16-May-25	2397107	TIB001	Ibisi Raw	Coliforms*	>2420	±22%	MPN/100mL
16-May-25	2397107	TIB001	Ibisi Raw	Coliphages*	12	±8%	PFU/10ml
16-May-25	2397106	TIB001	Ibisi Raw	Coll Time OS*	07:11	-	-
16-May-25	2397109	TIB001	Ibisi Raw	Conductivity	9.31	±1.5%	mS/m
16-May-25	2397107	TIB001	Ibisi Raw	E.coli*	88	±21%	MPN/100mL
16-May-25	2397106	TIB001	Ibisi Raw	pH OS*	7.50	-	-
16-May-25	2397106	TIB001	Ibisi Raw	Temperature OS*	18.2	-	°C
16-May-25	2397108	TIB001	Ibisi Raw	Turbidity	13.8	±6.1%	NTU
16-May-25	2397118	TRT001	Rietvlei Raw	Coliforms*	2420	±22%	MPN/100mL
16-May-25	2397117	TRT001	Rietvlei Raw	Coll Time OS*	06:27	-	-
16-May-25	2397120	TRT001	Rietvlei Raw	Conductivity	15.2	±1.5%	mS/m
16-May-25	2397118	TRT001	Rietvlei Raw	E.coli*	199	±21%	MPN/100mL
16-May-25	2397117	TRT001	Rietvlei Raw	pH OS*	7.50	-	-
16-May-25	2397117	TRT001	Rietvlei Raw	Temperature OS*	17.4	-	°C
16-May-25	2397119	TRT001	Rietvlei Raw	Turbidity	15.7	±6.1%	NTU
19-May-25	2398453	TFR001	Franklin Raw	Al (AE)	362	±7.6%	µg Al/L
19-May-25	2398450	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
19-May-25	2398450	TFR001	Franklin Raw	Coliphages*	345	±8%	PFU/10ml
19-May-25	2398449	TFR001	Franklin Raw	Coll Time OS*	08:58	-	-
19-May-25	2398451	TFR001	Franklin Raw	Colour	10.0	±6.5%	mg Pt-Co/L
19-May-25	2398452	TFR001	Franklin Raw	Conductivity	9.92	±1.5%	mS/m
19-May-25	2398450	TFR001	Franklin Raw	E.coli*	1414	±21%	MPN/100mL
19-May-25	2398453	TFR001	Franklin Raw	Fe (AE)	1.01	±5.4%	mg Fe/L
19-May-25	2398453	TFR001	Franklin Raw	Mn (AE)	<0.01	±6.2%	mg Mn/L
19-May-25	2398451	TFR001	Franklin Raw	Odour*	Nil	-	-
19-May-25	2398449	TFR001	Franklin Raw	pH OS*	7.00	-	-
19-May-25	2398449	TFR001	Franklin Raw	Temperature OS*	13.0	-	°C
19-May-25	2398451	TFR001	Franklin Raw	Turbidity	16.0	±6.1%	NTU
20-May-25	2399123	TQU001	Mnqumeni Raw	Coliforms*	1553	±22%	MPN/100mL
20-May-25	2399122	TQU001	Mnqumeni Raw	Coll Time OS*	08:03	-	-
20-May-25	2399125	TQU001	Mnqumeni Raw	Conductivity	11.3	±1.5%	mS/m
20-May-25	2399123	TQU001	Mnqumeni Raw	E.coli*	39	±21%	MPN/100mL
20-May-25	2399122	TQU001	Mnqumeni Raw	pH OS*	8.80	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

20-May-25	2399122	TQU001	Mnqumeni Raw	Temperature OS*	17.6	-	°C
20-May-25	2399124	TQU001	Mnqumeni Raw	Turbidity	9.7	±6.1%	NTU
20-May-25	2399135	TSQ001	Esiqanduleni Raw	Al (AE)	216	±7.6%	µg Al/L
20-May-25	2399132	TSQ001	Esiqanduleni Raw	Coliforms*	1553	±22%	MPN/100mL
20-May-25	2399132	TSQ001	Esiqanduleni Raw	Coliphages*	0	±8%	PFU/10ml
20-May-25	2399131	TSQ001	Esiqanduleni Raw	Coll Time OS*	07:00	-	-
20-May-25	2399133	TSQ001	Esiqanduleni Raw	Colour	2.90	±6.5%	mg Pt-Co/L
20-May-25	2399134	TSQ001	Esiqanduleni Raw	Conductivity	13.5	±1.5%	mS/m
20-May-25	2399132	TSQ001	Esiqanduleni Raw	E.coli*	18	±21%	MPN/100mL
20-May-25	2399135	TSQ001	Esiqanduleni Raw	Fe (AE)	0.19	±5.4%	mg Fe/L
20-May-25	2399135	TSQ001	Esiqanduleni Raw	Mn (AE)	<0.01	±6.2%	mg Mn/L
20-May-25	2399133	TSQ001	Esiqanduleni Raw	Odour*	Nil	-	-
20-May-25	2399131	TSQ001	Esiqanduleni Raw	pH OS*	7.50	-	-
20-May-25	2399131	TSQ001	Esiqanduleni Raw	Temperature OS*	18.2	-	°C
20-May-25	2399133	TSQ001	Esiqanduleni Raw	Turbidity	3.4	±6.1%	NTU
21-May-25	2399704	TBU001	Bulwer Raw	Al (AE)	684	±7.6%	µg Al/L
21-May-25	2399701	TBU001	Bulwer Raw	Coliforms*	>2420	±22%	MPN/100mL
21-May-25	2399700	TBU001	Bulwer Raw	Coll Time OS*	10:20	-	-
21-May-25	2399702	TBU001	Bulwer Raw	Colour	1.30	±6.5%	mg Pt-Co/L
21-May-25	2399703	TBU001	Bulwer Raw	Conductivity	5.89	±1.5%	mS/m
21-May-25	2399701	TBU001	Bulwer Raw	E.coli*	1203	±21%	MPN/100mL
21-May-25	2399702	TBU001	Bulwer Raw	Odour*	Nil	-	-
21-May-25	2399700	TBU001	Bulwer Raw	pH OS*	7.20	-	-
21-May-25	2399700	TBU001	Bulwer Raw	Temperature OS*	18.3	-	°C
21-May-25	2399702	TBU001	Bulwer Raw	Turbidity	50.7	±6.1%	NTU
21-May-25	2399718	TCR001	Creighton Raw	Al (AE)	122	±7.6%	µg Al/L
21-May-25	2399715	TCR001	Creighton Raw	Coliforms*	73	±22%	MPN/100mL
21-May-25	2399714	TCR001	Creighton Raw	Coll Time OS*	07:30	-	-
21-May-25	2399716	TCR001	Creighton Raw	Colour	1.30	±6.5%	mg Pt-Co/L
21-May-25	2399717	TCR001	Creighton Raw	Conductivity	6.91	±1.5%	mS/m
21-May-25	2399715	TCR001	Creighton Raw	E.coli*	2	±21%	MPN/100mL
21-May-25	2399714	TCR001	Creighton Raw	pH OS*	7.20	-	-
21-May-25	2399714	TCR001	Creighton Raw	Temperature OS*	13.1	-	°C
21-May-25	2399716	TCR001	Creighton Raw	Turbidity	2.6	±6.1%	NTU
21-May-25	2399735	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
21-May-25	2399734	THL001	Hlanganani Raw	Coll Time OS*	11:15	-	-
21-May-25	2399737	THL001	Hlanganani Raw	Conductivity	6.87	±1.5%	mS/m
21-May-25	2399735	THL001	Hlanganani Raw	E.coli*	517	±21%	MPN/100mL
21-May-25	2399734	THL001	Hlanganani Raw	pH OS*	7.20	-	-
21-May-25	2399734	THL001	Hlanganani Raw	Temperature OS*	16.2	-	°C
21-May-25	2399736	THL001	Hlanganani Raw	Turbidity	29.1	±6.1%	NTU
21-May-25	2399766	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

21-May-25	2399765	TMQA001	Mqatsheni Raw	Coll Time OS*	08:52	-	-
21-May-25	2399767	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
21-May-25	2399768	TMQA001	Mqatsheni Raw	Conductivity	27.3	±1.5%	mS/m
21-May-25	2399766	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
21-May-25	2399767	TMQA001	Mqatsheni Raw	Odour*	Nil	-	-
21-May-25	2399765	TMQA001	Mqatsheni Raw	pH OS*	9.80	-	-
21-May-25	2399765	TMQA001	Mqatsheni Raw	Temperature OS*	17.0	-	°C
21-May-25	2399767	TMQA001	Mqatsheni Raw	Turbidity	0.4	±6.1%	NTU
21-May-25	2399782	TRV001	Riversside Raw	Al (AE)	3589	±7.6%	µg Al/L
21-May-25	2399779	TRV001	Riversside Raw	Coliforms*	23	±22%	MPN/100mL
21-May-25	2399778	TRV001	Riversside Raw	Coll Time OS*	08:50	-	-
21-May-25	2399780	TRV001	Riversside Raw	Colour	2.90	±6.5%	mg Pt-Co/L
21-May-25	2399781	TRV001	Riversside Raw	Conductivity	7.55	±1.5%	mS/m
21-May-25	2399779	TRV001	Riversside Raw	E.coli*	0	±21%	MPN/100mL
21-May-25	2399778	TRV001	Riversside Raw	pH OS*	7.50	-	-
21-May-25	2399778	TRV001	Riversside Raw	Temperature OS*	12.5	-	°C
21-May-25	2399780	TRV001	Riversside Raw	Turbidity	4.9	±6.1%	NTU
21-May-25	2399797	TST001	St Appollinaris Raw	Al (AE)	150	±7.6%	µg Al/L
21-May-25	2399794	TST001	St Appollinaris Raw	Coliforms*	435	±22%	MPN/100mL
21-May-25	2399793	TST001	St Appollinaris Raw	Coll Time OS*	09:40	-	-
21-May-25	2399796	TST001	St Appollinaris Raw	Conductivity	7.69	±1.5%	mS/m
21-May-25	2399794	TST001	St Appollinaris Raw	E.coli*	28	±21%	MPN/100mL
21-May-25	2399793	TST001	St Appollinaris Raw	pH OS*	7.20	-	-
21-May-25	2399793	TST001	St Appollinaris Raw	Temperature OS*	14.7	-	°C
21-May-25	2399795	TST001	St Appollinaris Raw	Turbidity	3.0	±6.1%	NTU
21-May-25	2399808	TUN001	Underberg Raw	Al (AE)	47.8	±7.6%	µg Al/L
21-May-25	2399805	TUN001	Underberg Raw	Coliforms*	248	±22%	MPN/100mL
21-May-25	2399805	TUN001	Underberg Raw	Coliphages*	17	±8%	PFU/10ml
21-May-25	2399804	TUN001	Underberg Raw	Coll Time OS*	10:13	-	-
21-May-25	2399807	TUN001	Underberg Raw	Conductivity	6.41	±1.5%	mS/m
21-May-25	2399805	TUN001	Underberg Raw	E.coli*	109	±21%	MPN/100mL
21-May-25	2399804	TUN001	Underberg Raw	pH OS*	7.00	-	-
21-May-25	2399804	TUN001	Underberg Raw	Temperature OS*	13.5	-	°C
21-May-25	2399806	TUN001	Underberg Raw	Turbidity	1.3	±6.1%	NTU
22-May-25	2400394	TMZ001	Umzimkhulu Raw	Al (AE)	341	±7.6%	µg Al/L
22-May-25	2400391	TMZ001	Umzimkhulu Raw	Coliforms*	1300	±22%	MPN/100mL
22-May-25	2400391	TMZ001	Umzimkhulu Raw	Coliphages*	26	±8%	PFU/10ml
22-May-25	2400390	TMZ001	Umzimkhulu Raw	Coll Time OS*	08:12	-	-
22-May-25	2400393	TMZ001	Umzimkhulu Raw	Conductivity	9.49	±1.5%	mS/m
22-May-25	2400391	TMZ001	Umzimkhulu Raw	E.coli*	88	±21%	MPN/100mL
22-May-25	2400390	TMZ001	Umzimkhulu Raw	pH OS*	7.90	-	-
22-May-25	2400390	TMZ001	Umzimkhulu Raw	Temperature OS*	14.7	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

22-May-25	2400392	TMZ001	Umzimkhulu Raw	Turbidity	7.9	±6.1%	NTU
22-May-25	2400425	TNO001	Nokweja Raw	AI (AE)	309	±7.6%	µg AI/L
22-May-25	2400422	TNO001	Nokweja Raw	Coliforms*	1	±22%	MPN/100mL
22-May-25	2400422	TNO001	Nokweja Raw	Coliphages*	0	±8%	PFU/10ml
22-May-25	2400421	TNO001	Nokweja Raw	Coll Time OS*	08:30	-	-
22-May-25	2400424	TNO001	Nokweja Raw	Conductivity	9.63	±1.5%	mS/m
22-May-25	2400422	TNO001	Nokweja Raw	E.coli*	0	±21%	MPN/100mL
22-May-25	2400421	TNO001	Nokweja Raw	pH OS*	7.40	-	-
22-May-25	2400421	TNO001	Nokweja Raw	Temperature OS*	16.7	-	°C
22-May-25	2400423	TNO001	Nokweja Raw	Turbidity	6.4	±6.1%	NTU
22-May-25	2400446	TWA001	Washbank Raw	AI (AE)	1467	±7.6%	µg AI/L
22-May-25	2400443	TWA001	Washbank Raw	Coliforms*	>2420	±22%	MPN/100mL
22-May-25	2400442	TWA001	Washbank Raw	Coll Time OS*	07:16	-	-
22-May-25	2400445	TWA001	Washbank Raw	Conductivity	6.89	±1.5%	mS/m
22-May-25	2400443	TWA001	Washbank Raw	E.coli*	99	±21%	MPN/100mL
22-May-25	2400442	TWA001	Washbank Raw	pH OS*	9.20	-	-
22-May-25	2400442	TWA001	Washbank Raw	Temperature OS*	12.8	-	°C
22-May-25	2400444	TWA001	Washbank Raw	Turbidity	6.9	±6.1%	NTU
23-May-25	2400732	TIB001	Ibisi Raw	AI (AE)	2234375	±7.6%	µg AI/L
23-May-25	2400729	TIB001	Ibisi Raw	Coliforms*	0	±22%	MPN/100mL
23-May-25	2400729	TIB001	Ibisi Raw	Coliphages*	0	±8%	PFU/10ml
23-May-25	2400728	TIB001	Ibisi Raw	Coll Time OS*	07:40	-	-
23-May-25	2400731	TIB001	Ibisi Raw	Conductivity	432	±1.5%	mS/m
23-May-25	2400729	TIB001	Ibisi Raw	E.coli*	0	±21%	MPN/100mL
23-May-25	2400728	TIB001	Ibisi Raw	pH OS*	7.60	-	-
23-May-25	2400728	TIB001	Ibisi Raw	Temperature OS*	16.4	-	°C
23-May-25	2400730	TIB001	Ibisi Raw	Turbidity	9.6	±6.1%	NTU
23-May-25	2398478	TKK001	Kokstad River Raw	AI (AE)	31.0	±7.6%	µg AI/L
23-May-25	2398475	TKK001	Kokstad River Raw	Coliforms*	0	±22%	MPN/100mL
23-May-25	2398475	TKK001	Kokstad River Raw	Coliphages*	0	±8%	PFU/10ml
23-May-25	2398474	TKK001	Kokstad River Raw	Coll Time OS*	09:25	-	-
23-May-25	2398477	TKK001	Kokstad River Raw	Conductivity	27.7	±1.5%	mS/m
23-May-25	2398475	TKK001	Kokstad River Raw	E.coli*	0	±21%	MPN/100mL
23-May-25	2398474	TKK001	Kokstad River Raw	pH OS*	7.40	-	-
23-May-25	2398474	TKK001	Kokstad River Raw	Temperature OS*	12.3	-	°C
23-May-25	2398476	TKK001	Kokstad River Raw	Turbidity	0.4	±6.1%	NTU
23-May-25	2398489	TKK003	Kokstad Crystal Spring Raw	AI (AE)	208	±7.6%	µg AI/L
23-May-25	2398486	TKK003	Kokstad Crystal Spring Raw	Coliforms*	102	±22%	MPN/100mL
23-May-25	2398486	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
23-May-25	2398485	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	09:38	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

23-May-25	2398488	TKK003	Kokstad Crystal Spring Raw	Conductivity	8.06	±1.5%	mS/m
23-May-25	2398486	TKK003	Kokstad Crystal Spring Raw	E.coli*	2	±21%	MPN/100mL
23-May-25	2398485	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.10	-	-
23-May-25	2398485	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	12.1	-	°C
23-May-25	2398487	TKK003	Kokstad Crystal Spring Raw	Turbidity	10.9	±6.1%	NTU
23-May-25	2400745	TRT001	Rietvlei Raw	Coliforms*	>2420	±22%	MPN/100mL
23-May-25	2400744	TRT001	Rietvlei Raw	Coll Time OS*	09:10	-	-
23-May-25	2400747	TRT001	Rietvlei Raw	Conductivity	15.3	±1.5%	mS/m
23-May-25	2400745	TRT001	Rietvlei Raw	E.coli*	517	±21%	MPN/100mL
23-May-25	2400744	TRT001	Rietvlei Raw	pH OS*	7.90	-	-
23-May-25	2400744	TRT001	Rietvlei Raw	Temperature OS*	13.4	-	°C
23-May-25	2400746	TRT001	Rietvlei Raw	Turbidity	15.9	±6.1%	NTU
26-May-25	2402574	TFR001	Franklin Raw	AI (AE)	417	±7.6%	µg AI/L
26-May-25	2402571	TFR001	Franklin Raw	Coliforms*	1414	±22%	MPN/100mL
26-May-25	2402571	TFR001	Franklin Raw	Coliphages*	246	±8%	PFU/10ml
26-May-25	2402570	TFR001	Franklin Raw	Coll Time OS*	08:54	-	-
26-May-25	2402573	TFR001	Franklin Raw	Conductivity	9.74	±1.5%	mS/m
26-May-25	2402571	TFR001	Franklin Raw	E.coli*	579	±21%	MPN/100mL
26-May-25	2402570	TFR001	Franklin Raw	pH OS*	7.70	-	-
26-May-25	2402570	TFR001	Franklin Raw	Temperature OS*	10.8	-	°C
26-May-25	2402572	TFR001	Franklin Raw	Turbidity	9.6	±6.1%	NTU
26-May-25	2402594	TKK001	Kokstad River Raw	AI (AE)	553	±7.6%	µg AI/L
26-May-25	2402591	TKK001	Kokstad River Raw	Coliforms*	921	±22%	MPN/100mL
26-May-25	2402591	TKK001	Kokstad River Raw	Coliphages*	55	±8%	PFU/10ml
26-May-25	2402590	TKK001	Kokstad River Raw	Coll Time OS*	09:30	-	-
26-May-25	2402593	TKK001	Kokstad River Raw	Conductivity	12.7	±1.5%	mS/m
26-May-25	2402591	TKK001	Kokstad River Raw	E.coli*	345	±21%	MPN/100mL
26-May-25	2402590	TKK001	Kokstad River Raw	pH OS*	7.40	-	-
26-May-25	2402590	TKK001	Kokstad River Raw	Temperature OS*	15.7	-	°C
26-May-25	2402592	TKK001	Kokstad River Raw	Turbidity	14.7	±6.1%	NTU
26-May-25	2402605	TKK003	Kokstad Crystal Spring Raw	AI (AE)	540	±7.6%	µg AI/L
26-May-25	2402602	TKK003	Kokstad Crystal Spring Raw	Coliforms*	210	±22%	MPN/100mL
26-May-25	2402602	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
26-May-25	2402601	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	09:45	-	-
26-May-25	2402604	TKK003	Kokstad Crystal Spring Raw	Conductivity	8.32	±1.5%	mS/m
26-May-25	2402602	TKK003	Kokstad Crystal Spring Raw	E.coli*	6	±21%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

26-May-25	2402601	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.20	-	-
26-May-25	2402601	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	14.0	-	°C
26-May-25	2402603	TKK003	Kokstad Crystal Spring Raw	Turbidity	5.4	±6.1%	NTU
27-May-25	2403150	TQU001	Mnqumeni Raw	Coliforms*	659	±22%	MPN/100mL
27-May-25	2403149	TQU001	Mnqumeni Raw	Coll Time OS*	8:20	-	-
27-May-25	2403152	TQU001	Mnqumeni Raw	Conductivity	11.4	±1.5%	mS/m
27-May-25	2403150	TQU001	Mnqumeni Raw	E.coli*	55	±21%	MPN/100mL
27-May-25	2403149	TQU001	Mnqumeni Raw	pH OS*	8.60	-	-
27-May-25	2403149	TQU001	Mnqumeni Raw	Temperature OS*	15.0	-	°C
27-May-25	2403151	TQU001	Mnqumeni Raw	Turbidity	7.6	±6.1%	NTU
27-May-25	2403162	TSQ001	Esiqanduleni Raw	AI (AE)	112	±7.6%	µg AI/L
27-May-25	2403159	TSQ001	Esiqanduleni Raw	Coliforms*	548	±22%	MPN/100mL
27-May-25	2403159	TSQ001	Esiqanduleni Raw	Coliphages*	1	±8%	PFU/10ml
27-May-25	2403158	TSQ001	Esiqanduleni Raw	Coll Time OS*	7:59	-	-
27-May-25	2403161	TSQ001	Esiqanduleni Raw	Conductivity	14.6	±1.5%	mS/m
27-May-25	2403159	TSQ001	Esiqanduleni Raw	E.coli*	19	±21%	MPN/100mL
27-May-25	2403158	TSQ001	Esiqanduleni Raw	pH OS*	7.60	-	-
27-May-25	2403158	TSQ001	Esiqanduleni Raw	Temperature OS*	16.1	-	°C
27-May-25	2403160	TSQ001	Esiqanduleni Raw	Turbidity	2.5	±6.1%	NTU
28-May-25	2403591	TBU001	Bulwer Raw	AI (AE)	320	±7.6%	µg AI/L
28-May-25	2403588	TBU001	Bulwer Raw	Coliforms*	727	±22%	MPN/100mL
28-May-25	2403587	TBU001	Bulwer Raw	Coll Time OS*	10:26	-	-
28-May-25	2403589	TBU001	Bulwer Raw	Colour	1.30	±6.5%	mg Pt-Co/L
28-May-25	2403590	TBU001	Bulwer Raw	Conductivity	5.37	±1.5%	mS/m
28-May-25	2403588	TBU001	Bulwer Raw	E.coli*	260	±21%	MPN/100mL
28-May-25	2403587	TBU001	Bulwer Raw	pH OS*	7.60	-	-
28-May-25	2403587	TBU001	Bulwer Raw	Temperature OS*	11.0	-	°C
28-May-25	2403589	TBU001	Bulwer Raw	Turbidity	5.7	±6.1%	NTU
28-May-25	2403602	TCR001	Creighton Raw	AI (AE)	160	±7.6%	µg AI/L
28-May-25	2403599	TCR001	Creighton Raw	Coliforms*	66	±22%	MPN/100mL
28-May-25	2403598	TCR001	Creighton Raw	Coll Time OS*	08:27	-	-
28-May-25	2403600	TCR001	Creighton Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
28-May-25	2403601	TCR001	Creighton Raw	Conductivity	7.81	±1.5%	mS/m
28-May-25	2403599	TCR001	Creighton Raw	E.coli*	3	±21%	MPN/100mL
28-May-25	2403598	TCR001	Creighton Raw	pH OS*	7.60	-	-
28-May-25	2403598	TCR001	Creighton Raw	Temperature OS*	13.9	-	°C
28-May-25	2403600	TCR001	Creighton Raw	Turbidity	3.1	±6.1%	NTU
28-May-25	2403610	THL001	Hlanganani Raw	Coliforms*	579	±22%	MPN/100mL
28-May-25	2403609	THL001	Hlanganani Raw	Coll Time OS*	10:57	-	-
28-May-25	2403612	THL001	Hlanganani Raw	Conductivity	8.23	±1.5%	mS/m
28-May-25	2403610	THL001	Hlanganani Raw	E.coli*	62	±21%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

28-May-25	2403609	THL001	Hlanganani Raw	pH OS*	7.70	-	-
28-May-25	2403609	THL001	Hlanganani Raw	Temperature OS*	19.1	-	°C
28-May-25	2403611	THL001	Hlanganani Raw	Turbidity	8.0	±6.1%	NTU
28-May-25	2403624	TMAN001	Mangwaneni Raw	Coliforms*	1553	±22%	MPN/100mL
28-May-25	2403623	TMAN001	Mangwaneni Raw	Coll Time OS*	09:50	-	-
28-May-25	2403625	TMAN001	Mangwaneni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
28-May-25	2403626	TMAN001	Mangwaneni Raw	Conductivity	8.91	±1.5%	mS/m
28-May-25	2403624	TMAN001	Mangwaneni Raw	E.coli*	70	±21%	MPN/100mL
28-May-25	2403623	TMAN001	Mangwaneni Raw	pH OS*	7.60	-	-
28-May-25	2403623	TMAN001	Mangwaneni Raw	Temperature OS*	16.3	-	°C
28-May-25	2403625	TMAN001	Mangwaneni Raw	Turbidity	3.8	±6.1%	NTU
28-May-25	2403633	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL
28-May-25	2403632	TMQA001	Mqatsheni Raw	Coll Time OS*	07:20	-	-
28-May-25	2403634	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
28-May-25	2403635	TMQA001	Mqatsheni Raw	Conductivity	27.9	±1.5%	mS/m
28-May-25	2403633	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
28-May-25	2403632	TMQA001	Mqatsheni Raw	pH OS*	7.90	-	-
28-May-25	2403632	TMQA001	Mqatsheni Raw	Temperature OS*	14.2	-	°C
28-May-25	2403634	TMQA001	Mqatsheni Raw	Turbidity	0.5	±6.1%	NTU
28-May-25	2403645	TRV001	Riversside Raw	AI (AE)	2824	±7.6%	µg AI/L
28-May-25	2403642	TRV001	Riversside Raw	Coliforms*	30	±22%	MPN/100mL
28-May-25	2403641	TRV001	Riversside Raw	Coll Time OS*	09:05	-	-
28-May-25	2403643	TRV001	Riversside Raw	Colour	1.40	±6.5%	mg Pt-Co/L
28-May-25	2403644	TRV001	Riversside Raw	Conductivity	8.11	±1.5%	mS/m
28-May-25	2403642	TRV001	Riversside Raw	E.coli*	2	±21%	MPN/100mL
28-May-25	2403641	TRV001	Riversside Raw	pH OS*	7.30	-	-
28-May-25	2403641	TRV001	Riversside Raw	Temperature OS*	14.0	-	°C
28-May-25	2403643	TRV001	Riversside Raw	Turbidity	3.9	±6.1%	NTU
28-May-25	2403656	TST001	St Appollinaris Raw	AI (AE)	98.8	±7.6%	µg AI/L
28-May-25	2403653	TST001	St Appollinaris Raw	Coliforms*	261	±22%	MPN/100mL
28-May-25	2403652	TST001	St Appollinaris Raw	Coll Time OS*	09:48	-	-
28-May-25	2403655	TST001	St Appollinaris Raw	Conductivity	8.69	±1.5%	mS/m
28-May-25	2403653	TST001	St Appollinaris Raw	E.coli*	29	±21%	MPN/100mL
28-May-25	2403652	TST001	St Appollinaris Raw	pH OS*	7.50	-	-
28-May-25	2403652	TST001	St Appollinaris Raw	Temperature OS*	13.8	-	°C
28-May-25	2403654	TST001	St Appollinaris Raw	Turbidity	2.4	±6.1%	NTU
29-May-25	2404267	TMZ001	Umzimkhulu Raw	AI (AE)	266	±7.6%	µg AI/L
29-May-25	2404264	TMZ001	Umzimkhulu Raw	Coliforms*	579	±22%	MPN/100mL
29-May-25	2404264	TMZ001	Umzimkhulu Raw	Coliphages*	24	±8%	PFU/10ml
29-May-25	2404263	TMZ001	Umzimkhulu Raw	Coll Time OS*	08:38	-	-
29-May-25	2404266	TMZ001	Umzimkhulu Raw	Conductivity	9.66	±1.5%	mS/m
29-May-25	2404264	TMZ001	Umzimkhulu Raw	E.coli*	41	±21%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

29-May-25	2404263	TMZ001	Umzimkhulu Raw	pH OS*	7.90	-	-
29-May-25	2404263	TMZ001	Umzimkhulu Raw	Temperature OS*	14.9	-	°C
29-May-25	2404265	TMZ001	Umzimkhulu Raw	Turbidity	6.0	±6.1%	NTU
29-May-25	2404278	TNO001	Nokweja Raw	Al (AE)	217	±7.6%	µg Al/L
29-May-25	2404275	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
29-May-25	2404275	TNO001	Nokweja Raw	Coliphages*	49	±8%	PFU/10ml
29-May-25	2404274	TNO001	Nokweja Raw	Coll Time OS*	09:14	-	-
29-May-25	2404277	TNO001	Nokweja Raw	Conductivity	10.1	±1.5%	mS/m
29-May-25	2404275	TNO001	Nokweja Raw	E.coli*	1414	±21%	MPN/100mL
29-May-25	2404274	TNO001	Nokweja Raw	pH OS*	7.50	-	-
29-May-25	2404274	TNO001	Nokweja Raw	Temperature OS*	15.2	-	°C
29-May-25	2404276	TNO001	Nokweja Raw	Turbidity	4.2	±6.1%	NTU
29-May-25	2404289	TWA001	Washbank Raw	Al (AE)	1463	±7.6%	µg Al/L
29-May-25	2404286	TWA001	Washbank Raw	Coliforms*	>2420	±22%	MPN/100mL
29-May-25	2404285	TWA001	Washbank Raw	Coll Time OS*	08:02	-	-
29-May-25	2404288	TWA001	Washbank Raw	Conductivity	6.90	±1.5%	mS/m
29-May-25	2404286	TWA001	Washbank Raw	E.coli*	14	±21%	MPN/100mL
29-May-25	2404285	TWA001	Washbank Raw	pH OS*	8.50	-	-
29-May-25	2404285	TWA001	Washbank Raw	Temperature OS*	14.4	-	°C
29-May-25	2404287	TWA001	Washbank Raw	Turbidity	5.7	±6.1%	NTU
30-May-25	2404481	TIB001	Ibisi Raw	Al (AE)	4520	±7.6%	µg Al/L
30-May-25	2404478	TIB001	Ibisi Raw	Coliforms*	687	±22%	MPN/100mL
30-May-25	2404478	TIB001	Ibisi Raw	Coliphages*	0	±8%	PFU/10ml
30-May-25	2404477	TIB001	Ibisi Raw	Coll Time OS*	08:36	-	-
30-May-25	2404480	TIB001	Ibisi Raw	Conductivity	9.16	±1.5%	mS/m
30-May-25	2404478	TIB001	Ibisi Raw	E.coli*	36	±21%	MPN/100mL
30-May-25	2404477	TIB001	Ibisi Raw	pH OS*	7.50	-	-
30-May-25	2404477	TIB001	Ibisi Raw	Temperature OS*	15.2	-	°C
30-May-25	2404479	TIB001	Ibisi Raw	Turbidity	17.2	±6.1%	NTU
30-May-25	2404489	TRT001	Rietvlei Raw	Coliforms*	2420	±22%	MPN/100mL
30-May-25	2404488	TRT001	Rietvlei Raw	Coll Time OS*	07:37	-	-
30-May-25	2404491	TRT001	Rietvlei Raw	Conductivity	15.5	±1.5%	mS/m
30-May-25	2404489	TRT001	Rietvlei Raw	E.coli*	113	±21%	MPN/100mL
30-May-25	2404488	TRT001	Rietvlei Raw	pH OS*	7.50	-	-
30-May-25	2404488	TRT001	Rietvlei Raw	Temperature OS*	14.1	-	°C
30-May-25	2404490	TRT001	Rietvlei Raw	Turbidity	14.7	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)